

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id GZJ00403 Component

Biogas Engine

PETRO CANADA SENTRON CG 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Fluid

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0699019	WC0699025	WC0699081
Sample Date		Client Info		13 Mar 2023	07 Mar 2023	27 Feb 2023
Machine Age	hrs	Client Info		112879	112735	112546
Oil Age	hrs	Client Info		261	117	904
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	3	2	11
Chromium	ppm	ASTM D5185m	>2	<1	0	<1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>5	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	3
Lead	ppm	ASTM D5185m	>5	<1	0	3
Copper	ppm	ASTM D5185m	>14	<1	<1	3
Tin	ppm	ASTM D5185m	>13	2	<1	6
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	1	<1	0
Barium	ppm	ASTM D5185m	1	0	0	0
Molybdenum	ppm	ASTM D5185m	2	1	<1	2
Manganese	ppm	ASTM D5185m	1	<1	<1	<1
Magnesium	ppm	ASTM D5185m	9	14	14	13
Calcium	ppm	ASTM D5185m	2712	2734	2571	2886
Phosphorus	ppm	ASTM D5185m	292	263	251	274
Zinc	ppm	ASTM D5185m	342	322	305	353
Sulfur	ppm	ASTM D5185m	2575	3772	3153	3876
CONTAMINANTS	8	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	148	83	4 01
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Fuel	%	ASTM D3524	>4.0	0.3	0.4	0.3
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	4.6	5.8	5.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	16.8	19.1	20.8
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	8.9	12.2	11.6
Acid Number (AN)	mg KOH/g	ASTM D8045	0.98	0.62	0.406	1.18
Base Number (BN)	mg KOH/g	ASTM D2896	8.1	7.87	8.07	7.08
6:56:00) Rev: 1					Submitted By:	Blain Middleton


Submitted By: Blain Middleton




OIL ANALYSIS REPORT









					N	VISUAL				met	thod	limit/bas	se	current		history1		history2
					W	hite Met	al		scalar	*Visu	ıal	NONE		NONE	Ν	ONE		NONE
					Ye	ellow Me	etal		scalar	*Visu	ial	NONE		NONE	N	ONE		NONE
						ecipitate			scalar	*Visu	ial	NONE		NONE		ONE		NONE
+÷+			++++		Si	lt			scalar	*Visu	ıal	NONE		NONE	Ν	ONE		NONE
					De	ebris			scalar	*Visu	ıal	NONE		NONE	Ν	ONE		NONE
-		_			Sa	and/Dirt			scalar	*Visu	ıal	NONE		NONE	N	ONE		NONE
Sep12/22	0ct17/22	Nov28/22	Jan3/23 -	Feb 13/23	Ap	opearan	се		scalar	*Visu	ual	NORML		NORML	Ν	ORML		NORML
Sep1	0ct1	Nov2	Jan	Feb1	O	dor			scalar	*Visu	ıal	NORML		NORML	N	ORML		NORML
					Er	nulsified	l Wate	er	scalar	*Visu	ıal	>0.1		NEG	Ν	EG		NEG
	Л				Fr	ee Wate	er		scalar	*Visu	ıal			NEG	N	EG		NEG
1	4	A	A	A	F	FLUID F	PROP	ERT	IES	met	thod	limit/bas	se	current		history1		history2
V		11	11	N I.	Vi	sc @ 10	0°C		cSt	ASTN	1 D445	13.5		13.3	1	3.3		13.4
				. 1		GRAPH												
] 100т	iron (pp	m)						10	ead (ppm)			
122 -	/22	/22	/23 -	123		Severe							8-	Severe	+ +			
Sep12/22	0ct17/22	Nov28/22	Jan3/23	Feb13/23	0.0								E 6-	Abnormal				
				42.00.74	40 to 1	Abnormal							udd 4		+			Â
					20-					~	~		2-	~~~	M	M	N	IM
		A .		~~~~~~	L 0	22	22	22	-22	22		~	0	22		22	122	23
1	5	٧V	\searrow	U	COLCW	Jul6/22	Aug8/22	Sep 12/22	0ct17/22	Nov28/22	Jan 3/23 Feh 1 3/23		CC115/mEM	Jul6/22	Aug8/22 Sep12/22	0ct17/22	Nov28/22	Jan3/23 Feb13/23
						² Aluminu	m (pp			~				: Chromium			2	2012
					20 T	Severe	. APP						⁵ T		(FF)			10000100
					15-	0							444	Severe		1		
22	22	22	23 -	23	튭 10 -	Abnormal							udd 2	Abnormal				
Sep12/22	0ct17/22	Nov28/22	Jan3/23	Feb13/23	5-								2-4			~		
	0	2		LL.	0	\sim	\sim	\sim	$\sim \sim$	\sim	1	\sim		~	~	SV	~	n
°C						Jul6/22	Aug8/22	Sep12/22	7/22	8/22	Jan3/23	5	1001	Jul6/22	Aug8/22 - Sep12/22 -	0ct17/22	8/22	Jan 3/23 -
					correction M	lul (ul	Bng	Sep 1	0ct17/22	Nov28/22	Jan3/23 Feh13/23		Mar 21/22	InL	Aug Sep1.	0ct1	Nov28/22	Jan3/23 Feb13/23
					0.0	Copper	(ppm))						Silicon (pp	m)			
					30 25 -	Severe						11111	600 500				٨	1
~					20-	~							400 -	Λ	A	1	1	1 n
					100	Abnormal		+++++				-	튭 300 - 6	Abnormal	1/1	11	17	1/1
2	2	2			10-	1-	1	1					200 - d	V	VI	1 V	V	VI
Sep12/22	0ct17/22	Nov28/22	Jan3/23	Feb13/23	ΰL		V		~	~	1	~	٥L				~	
Se	ŏ	No	7	æ	CC 10-14	ays 1/22 Jul6/22	Aug8/22	Sep 12/22	0ct17/22	Nov28/22	Jan3/23 Feh13/23		Mav31.02	Jul6/22	Aug8/22 Sep12/22	0ct17/22	Nov28/22	Jan3/23 Feb13/23
									õ	No		-				õ	No	っ ア ア ア
					¹⁸ T	Viscosity	(@ I(JUSC	nnnpras				10.0 -	Base Numl	ber	ana pasa		
					10+	Abnormal						Base Mumber (mo KOH/o)	8.0-	Base	~	~	AA	7777
					00°C)	Race						r (ma	6.0	\sim	~	~	V	~ ~
						Abnormal		~					4.0-					
					12-							au au	2.0-					
					10 L	/22	/22 -	22	122 -	/22 -	73-		0.0	/22 -	122 +	122-	/22 +	/23 -
					0.10.11	Jul6/22	Aug8/22	Sep12/22	0ct17/22	Nov28/22	Jan3/23 Feh13/23		Mav21.02	Jul6/22	Aug8/22 Sep12/22	0ct17/22	Nov28/22	Jan3/23 Feb13/23
			1-1						Mart		0							
_	4			oratory		arCheck 069901		- 501		on Ave. e ived		, NC 2751 Mar 2023			74			OENERG
A	CREDI	TED				92983	~		Test			Mar 2020			1.11			ardman, C
т	ESTING LABORAT	TORY	Uniq	ue Number	: 103	77654			Diag	nosed	: 17	Mar 2023 -	Sean	Felton				US 978
	ertificate Li			t Package)		I			n Middlete
				ple report, thods that											na	nacieton		aea.ener 1)481-32
				ormity to si									ion ru	In (ICGM	106.201	2)		1)-01 02

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Page 2 of 2

F: