

PROBLEM SUMMARY

Sample Rating Trend


DIRT

Machine Id **2037271 (S/N 1524)**


Component


Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)









RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL					
Silicon	ppm	ASTM D5185m	>25	△ 36	4	13					
Particles >6µm		ASTM D7647	>1300	16891	▲ 7492						
Particles >14µm		ASTM D7647	>80	^ 2108	<u>1436</u>						
Particles >21µm		ASTM D7647	>20	419	<u></u> 411						
Particles >38µm		ASTM D7647	>4	△ 33	△ 39						
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/18</u>	<u>\$\rightarrow\$ 21/20/18</u>						

Customer Id: PERROS Sample No.: KCP54276 Lab Number: 05794534 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

26 Sep 2022 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



14 Jun 2021 Diag: Doug Bogart

VIS DEBRIS




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



DIRT

2037271 (S/N 1524)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jur	2021	Sep2022 Mar20	23	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP54276	KCP50094	KCP33169
Sample Date		Client Info		07 Mar 2023	26 Sep 2022	14 Jun 2021
Machine Age	hrs	Client Info		149343	145504	139723
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	3	4	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	5	4
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	13
Barium	ppm	ASTM D5185m	90	19	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	55	4	6
Calcium	ppm	ASTM D5185m	0	0	0	<1
Phosphorus	ppm	ASTM D5185m	0	2	0	7
Zinc	ppm	ASTM D5185m	0	6	25	12
Sulfur	ppm	ASTM D5185m	23500	20803	19123	16587
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm		>25	<u>^</u> 36	4	13
Sodium	ppm	ASTM D5185m	00	23	2	3
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.05	0.012	0.007	0.002
ppm Water	ppm	ASTM D6304	>500	129.1	74.8	24.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		34506	16885	
Particles >6µm		ASTM D7647		<u>^</u> 16891	<u>^</u> 7492	
Particles >14μm		ASTM D7647	>80	<u>^</u> 2108	<u> </u>	
Particles >21µm		ASTM D7647	>20	<u>419</u>	<u>411</u>	
Particles >38μm		ASTM D7647	>4	33	4 39	
Particles >71μm		ASTM D7647	>3	2	A 3	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/18</u>	△ 21/20/18	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT

