

PROBLEM SUMMARY

Sample Rating Trend


ISO

Machine Id KAESER SK 26 2345893 (S/N 1022)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL				
Particles >6μm	ASTM D7647	>1300	10644	<u>^</u> 7163	<u>▲</u> 5297				
Particles >14μm	ASTM D7647	>80	1248	▲ 726	<u></u> ▲ 569				
Particles >21µm	ASTM D7647	>20	^ 288	<u>^</u> 217	<u>▲</u> 163				
Particles >38μm	ASTM D7647	>4	<u> </u>	<u> </u>	10				
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>^</u> 22/21/17	<u>^</u> 20/17	<u>^</u> 20/16				

Customer Id: COLBOU Sample No.: KCP54708 Lab Number: 05794545 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

28 Apr 2021 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



11 Feb 2020 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

31 Dec 2018 Diag: Jonathan Hester

VIS DEBRIS




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



ISO

KAESER SK 26 2345893 (S/N 1022)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		Jan2016	Jun2017 Dec2018	Feb2020 Apr2021	Feb 2023	
SAMPLE INFORMA	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP54708	KCP30134	KCP25353
Sample Date		Client Info		24 Feb 2023	28 Apr 2021	11 Feb 2020
Machine Age	hrs	Client Info		82692	71724	69271
Oil Age	hrs	Client Info		3000	8	7421
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	1	<1
Lead	ppm	ASTM D5185m	>10	0	1	<1
Copper	ppm	ASTM D5185m	>50	1	1	3
	ppm	ASTM D5185m	>10	0	0	0
	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	71	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	100	23	88	23
Calcium	ppm	ASTM D5185m	0	0	0	0
	ppm	ASTM D5185m	0	3	<1	<1
Zinc	ppm	ASTM D5185m	0	13	6	36
Sulfur	ppm	ASTM D5185m	23500	22653	19925	20123
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	0
Sodium	ppm	ASTM D5185m		4	7	11
	ppm	ASTM D5185m	>20	0	4	2
	%	ASTM D6304	>0.05	0.008	0.029	0.012
ppm Water	ppm	ASTM D6304	>500	86.7	290.0	124.7
FLUID CLEANLINE	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		25753	38153	15092
Particles >6μm		ASTM D7647	>1300	<u> </u>	<u>▲</u> 7163	▲ 5297
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>▲</u> 726	<u></u> ▲ 569
Particles >21μm		ASTM D7647	>20	288	<u>^</u> 217	<u>▲</u> 163
Particles >38μm		ASTM D7647	>4	<u>^</u> 20	<u>12</u>	10
Particles >71μm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/17</u>	<u>^</u> 20/17	△ 20/16
FLUID DEGRADAT	ΓΙΟΝ	method	limit/base	current	history1	history2


0.338

0.43

0.442



OIL ANALYSIS REPORT



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: