

Area
Red Bluff Plant/Cryogenic/Compressor
 Machine Id
GEA FES C-261
 Component
Rotary Compressor
 Fluid
SUMMIT PGI 100 (250 GAL)

DIAGNOSIS

Recommendation
 We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a high amount of particulates present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO90002294	TO90000693	TO90001650
Sample Date	Client Info	14 Mar 2023	08 Mar 2022	20 Dec 2021
Machine Age	hrs Client Info	0	0	0
Oil Age	hrs Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >70	8	6	4
Chromium	ppm ASTM D5185m >10	1	0	0
Nickel	ppm ASTM D5185m	1	0	<1
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m	0	<1	<1
Aluminum	ppm ASTM D5185m >3	1	<1	0
Lead	ppm ASTM D5185m >4	0	0	<1
Copper	ppm ASTM D5185m >20	0	0	0
Tin	ppm ASTM D5185m >3	<1	3	2
Antimony	ppm ASTM D5185m	---	1	2
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	2	0
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	<1	0	0
Manganese	ppm ASTM D5185m	<1	0	0
Magnesium	ppm ASTM D5185m	0	0	1
Calcium	ppm ASTM D5185m	0	0	<1
Phosphorus	ppm ASTM D5185m	61	456	371
Zinc	ppm ASTM D5185m	0	8	9
Sulfur	ppm ASTM D5185m	0	22	28

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >45	1	<1	1
Sodium	ppm ASTM D5185m	0	<1	0
Potassium	ppm ASTM D5185m >20	<1	0	0
Water	% ASTM D6304 >0.6	0.015	0.006	0.063
ppm Water	ppm ASTM D6304	153.9	60.9	632.7






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	▲ 174982	▲ 7469	1515
Particles >6µm	ASTM D7647 >320	▲ 30853	▲ 1592	312
Particles >14µm	ASTM D7647 >80	▲ 83	▲ 92	19
Particles >21µm	ASTM D7647 >20	13	▲ 22	3
Particles >38µm	ASTM D7647 >4	0	0	0
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >18/15/13	▲ 25/22/14	▲ 20/18/14	18/15/11

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	0.06	0.055	0.027

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	105	101
Visc @ 100°C	cSt	ASTM D445	18.6	18.0	18.1
Viscosity Index (VI)	Scale	ASTM D2270	185	190	198

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90002294
Lab Number : 05797422
Unique Number : 10387106
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)
Received : 21 Mar 2023
Tested : 22 Mar 2023
Diagnosed : 23 Mar 2023 - Doug Bogart

ENERGY TRANSFER - RED BLUFF/ORLA PLANT
 770 CR 437
 ORLA, TX
 US 79770
 Contact: STUART TAYLOR
 stuart.taylor@energytransfer.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)