


## **OIL ANALYSIS REPORT**

PALASYN 45
Machine Id
SULLIVAN PALATEK 22JE003390 - THE GEAR SHOP

Component

Compressor



#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Moor

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil


### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCS05797628		
Sample Date		Client Info		14 Mar 2023		
Machine Age	hrs	Client Info		843		
Oil Age	hrs	Client Info		843		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.0	0		
Barium	ppm	ASTM D5185m	0.0	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m	0	0		
Magnesium	ppm	ASTM D5185m	0.0	0		
Calcium	ppm	ASTM D5185m	0.0	0		
Phosphorus	ppm	ASTM D5185m	966	649		
Zinc	ppm	ASTM D5185m	0	2		
Sulfur	ppm	ASTM D5185m	1309	1511		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.172	0.203		

# **Sullivan**

## **OIL ANALYSIS REPORT**









Certificate L2367

Laboratory Sample No.

Lab Number : 05797628 Unique Number : 10387312 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCS05797628

Viscosity @ 40°C

Received **Tested** 

Diagnosed

: 21 Mar 2023 : 22 Mar 2023 : 23 Mar 2023 - Don Baldridge

Mar14/23 -

0.25 (B) (B) (D) (D) E 0.15 흩 0.10 0.05 0.00 Acid Number

AIR COMPRESSOR SERVICES OF MARYLAND

JOPPA, MD US 21085 Contact: CHRIS SCHAUM

aircompservmd@verizon.net T: (410)633-0900

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (410)633-0901 Contact/Location: CHRIS SCHAUM - UCAIRJOP