




PROBLEM SUMMARY

Sample Rating Trend



WATER




Machine Id WET END OUTER FAN

Component
Hydraulic System

Fluid
AW HYDRAULIC OIL ISO 68 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	NORMAL
Water	%	ASTM D6304	>0.05	▲ 0.077	▲ 0.220	---
ppm Water	ppm	ASTM D6304	>500	▲ 770	▲ 2200	---
Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	0.2%	NEG
Free Water	scalar	*Visual		● >10%	▲ 1.0	NEG

Customer Id: BLUDAN
 Sample No.: WC0800294
 Lab Number: 05799652
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

29 Oct 2022 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Free water present. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



10 Jun 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



19 Apr 2022 Diag: Don Baldrige

VIS DEBRIS



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
WET END OUTER FAN

Component
Hydraulic System

Fluid
AW HYDRAULIC OIL ISO 68 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

Wear

All component wear rates are normal.

Contamination

There is a trace of moisture present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0800294	WC0749086	WC0699090
Sample Date	Client Info	10 Mar 2023	29 Oct 2022	10 Jun 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	4	3	<1
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >20	<1	0	<1
Lead	ppm	ASTM D5185m >20	<1	<1	0
Copper	ppm	ASTM D5185m >20	1	1	4
Tin	ppm	ASTM D5185m >20	1	1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 5	0	0	0
Barium	ppm	ASTM D5185m 5	0	0	0
Molybdenum	ppm	ASTM D5185m 5	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m 25	<1	0	<1
Calcium	ppm	ASTM D5185m 200	1	0	0
Phosphorus	ppm	ASTM D5185m 300	27	47	40
Zinc	ppm	ASTM D5185m 370	5	0	0
Sulfur	ppm	ASTM D5185m 2500	190	18	179

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	1	0	<1
Sodium	ppm	ASTM D5185m	0	1	<1
Potassium	ppm	ASTM D5185m >20	1	0	0
Water	%	ASTM D6304 >0.05	▲ 0.077	▲ 0.220	---
ppm Water	ppm	ASTM D6304 >500	▲ 770	▲ 2200	---

FLUID CLEANLINESS




method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	---	4476	3181
Particles >6µm	ASTM D7647 >1300	---	▲ 2438	890
Particles >14µm	ASTM D7647 >160	---	▲ 415	91
Particles >21µm	ASTM D7647 >40	---	▲ 140	25
Particles >38µm	ASTM D7647 >10	---	▲ 22	4
Particles >71µm	ASTM D7647 >3	---	▲ 2	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	---	▲ 19/18/16	19/17/14

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.57	0.08	0.063	0.054




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	0.2%
Free Water	scalar	*Visual		● >10%	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 68	65.2	65.0	64.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0800294 **Received** : 23 Mar 2023
Lab Number : 05799652 **Diagnosed** : 28 Mar 2023
Unique Number : 10389336 **Diagnostician** : Don Baldridge
Test Package : IND 2 (Additional Tests: KF)

BLUE RIDGE FIBERBOARD
 250 KNIGHT CELOTEX DR
 DANVILLE, VA
 US 24541

Contact: Jerald Caldwell
 JCaldwell@blueridgefiberboard.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: