

PROBLEM SUMMARY


Sample Rating Trend

WATER

ContiTech USA_Lincoln #3 Calender Bearing Oil


Component Circulating System


NOCOLUB-MOBILGEAR 600 XP 460 (--- GAL)






COMPONENT CONDITION SUMMARY







RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

PROBLEMATIC TEST RESULTS										
Sample Status				SEVERE	NORMAL	SEVERE				
Iron	ppm	ASTM D5185m		△ 312	0	0				
Water	%	ASTM D6304		1.56	0.003	0				
ppm Water	ppm	ASTM D6304		15600						
White Metal	scalar	*Visual	NONE	HEAVY						
Debris	scalar	*Visual	NONE	▲ MODER						
Appearance	scalar	*Visual	NORML	MILKY						
Free Water	scalar	*Visual		10.0						
Visc @ 40°C	cSt	ASTM D445	460	737	476	735.4				

Customer Id: CON4021LIN Sample No.: SBP0000556 Lab Number: 05801629 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS Action **Status** Date Done By Description ? Inspect Wear Source We advise that you inspect for the source(s) of wear. We recommend that you drain the oil from the component if this has not Change Fluid ? already been done. ? Resample We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in Alert ? this sample. **Check Water Access** We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

03 Apr 2021 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report

03 Aug 2020 Diag: Wes Davis

VISCOSITY



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 680 range, advise investigate. The condition of the oil is acceptable for the time in service.

view report

26 Sep 2019 Diag: Wes Davis

VISCOSITY




Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT



WATER



ContiTech USA_Lincoln Machine Id #3 Calender Bearing Oil

Component

Circulating System

NOCOLUB-MOBILGEAR 600 XP 460 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to metal particles present in this sample.

Wear

An increase in the iron level is noted. High concentration of visible metal present.

Contamination

Moderate concentration of visible dirt/debris present in the oil. There is a high concentration of water present in the oil. Excessive free water present.


Fluid Condition

The oil viscosity is higher than normal. The oil is no longer serviceable due to the presence of contaminants.

AL)		Sep 2017	Apr2019 Sep2019	Aug2020 Apr2021	Mar2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		SBP0000556	SBP16229067	SBP16487032
Sample Date		Client Info		19 Mar 2023	03 Apr 2021	03 Aug 2020
Machine Age	hrs	Client Info		27727	0	0
Oil Age	hrs	Client Info		27727	0	0
Oil Changed		Client Info		N/A	Not Changd	N/A
Sample Status				SEVERE	NORMAL	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		1125	3	
Iron	ppm	ASTM D5185m		<u> 312</u>	0	0
Chromium	ppm	ASTM D5185m		2	0	0
Nickel	ppm	ASTM D5185m		2	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		4	0	0
Lead	ppm	ASTM D5185m		1	0	0
Copper	ppm	ASTM D5185m		8	0	0
Tin	ppm	ASTM D5185m		<1	1	1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	23	4
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		1	0	0
Manganese	ppm	ASTM D5185m		3	0	0
Magnesium	ppm	ASTM D5185m		10	0	0
Calcium	ppm	ASTM D5185m		45	1	1
Phosphorus	ppm	ASTM D5185m		190	247	156
Zinc	ppm	ASTM D5185m		10	4	0
Sulfur	ppm	ASTM D5185m		7579		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		26	1	1
Sodium	ppm	ASTM D5185m		30	1	0
Potassium	ppm	ASTM D5185m	>20	4	1	0
Chlorine	ppm	ASTM D5185m			0	0
Water	%	ASTM D6304		1.56	0.003	0
ppm Water	ppm	ASTM D6304		15600		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000		2903	
Particles >6µm		ASTM D7647	>1300		529	
Particles >14µm		ASTM D7647	>160		28	
Oil Cleanliness		ISO 4406 (c)	>19/17/14		19/16/12	
·	TION		>19/17/14 limit/base	current	19/16/12 history1	history2



OIL ANALYSIS REPORT



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: