


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Oil Gear PVWH VLSTT

Component

Bulk Fluid Tank

CITGO HYTHERM 46 (110 GAL)

Ν		

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: Filter installed 18 Sep 2019

First sample after OK lab closed Tests N2STV4W)

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


				Mar2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PH0000378		
Sample Date		Client Info		23 Mar 2023		
Machine Age		Client Info		417		
Oil Age		Client Info		0		
Oil Changed		Client Info		Filtered		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m		0		
Chromium	ppm	ASTM D5185m		0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m		<1		
_ead	ppm	ASTM D5185m		<1		
Copper	ppm	ASTM D5185m		1		
Борреі Гіп	ppm	ASTM D5185m		0		
/anadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES	рріп	method	limit/base	current	historyt	history2
			IIIIII/Dase		history1	
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		2		
Phosphorus	ppm	ASTM D5185m		672		
Zinc	ppm	ASTM D5185m		2		
Sulfur	ppm	ASTM D5185m		1596		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		2		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	491		
Particles >6µm		ASTM D7647	>1300	74		
Particles >14µm		ASTM D7647	>160	6		
Particles >21µm		ASTM D7647	>40	3		
Particles >38µm		ASTM D7647	>10	0		
Particles >71µm		ASTM D7647	>3	0		
Dil Cleanliness		ISO 4406 (c)	>19/17/14	16/13/10		
FLUID DEGRADA	ATION_	method	limit/base	current	history1	history2
	та КОЦ/а	ACTM DODAE	0.04	0.24	<u></u>	,

0.24

Acid Number (AN) mg KOH/g ASTM D8045 0.01



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: PH0000378 : 05805583

Received Diagnosed : 10403112 Diagnostician : Doug Bogart

: 29 Mar 2023

: 30 Mar 2023

Test Package : PLANT (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FIDELITY TECHNOLOGIES FOR NSTCP

94-1017 MOLALE STREET WAIPAHU, HI US 96797

Contact: WILLIAM DUNN

dunnd@fidelitytech.com

T: F: