




# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**MTNM01BE**  
Component  
**Biogas Engine**  
Fluid  
**SHELL SHELL MYSELLA S3 N 40 (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you check the air filter, air induction system, and any areas where dirt may enter the component. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0770244</b>	WC0770223	WC0770159
Sample Date	Client Info		<b>07 Apr 2023</b>	30 Mar 2023	22 Mar 2023
Machine Age	hrs	Client Info	<b>37826</b>	75785	37688
Oil Age	hrs	Client Info	<b>528</b>	19	390
Oil Changed	Client Info		<b>Changed</b>	N/A	Changed
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>7</b>	1	6
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>&lt;1</b>	2	3
Lead	ppm	ASTM D5185m	>9	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m	>6	<b>1</b>	<1	1
Tin	ppm	ASTM D5185m	>4	<b>4</b>	<1	3
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>3</b>	4	4
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>2</b>	5	2
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>17</b>	22	17
Calcium	ppm	ASTM D5185m		<b>1732</b>	1346	1611
Phosphorus	ppm	ASTM D5185m		<b>350</b>	299	324
Zinc	ppm	ASTM D5185m		<b>449</b>	351	429
Sulfur	ppm	ASTM D5185m		<b>3269</b>	3191	2915

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>▲ 182</b>	22	149
Sodium	ppm	ASTM D5185m		<b>0</b>	2	0
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	<1	2

## INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>5.7</b>	3.3	5.6
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>23.1</b>	16.6	23.2

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>16.9</b>	10.1	16.7
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>1.28</b>	0.62	1.23
Base Number (BN)	mg KOH/g	ASTM D2896	5	<b>4.09</b>	4.88	3.73











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.7	13.1

### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0770244 **Received** : 11 Apr 2023  
**Lab Number** : 05816651 **Diagnosed** : 13 Apr 2023  
**Unique Number** : 10419443 **Diagnostician** : Angela Borella  
**Test Package** : MOB 2

**EDL NA Recips-Morgantown**  
 Morgantown Powerstation, 950 Shiloh  
 Morgantown, PA  
 US 19543  
 Contact: ARON GUNN  
 aron.gunn@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: