



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
04

Machine Id


[04] BASELINE - TURBINE LIFE 68 REF

Component

New (Unused) Oil

Fluid

High Performance Lubricants Turbine Life 68 (1 QTS)



DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. (Customer Sample Comment: Batch#22L1601)

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		HPL0003345	HPL008195	---
Sample Date	Client Info		11 Apr 2023	29 Jun 2021	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			NORMAL	NORMAL	---

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method		NEG	NEG	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	0	0	---
Chromium	ppm	ASTM D5185m	0	0	---
Nickel	ppm	ASTM D5185m	0	0	---
Titanium	ppm	ASTM D5185m	0	0	---
Silver	ppm	ASTM D5185m	0	<1	---
Aluminum	ppm	ASTM D5185m	0	<1	---
Lead	ppm	ASTM D5185m	0	0	---
Copper	ppm	ASTM D5185m	0	<1	---
Tin	ppm	ASTM D5185m	0	0	---
Antimony	ppm	ASTM D5185m	---	0	---
Vanadium	ppm	ASTM D5185m	0	0	---
Cadmium	ppm	ASTM D5185m	0	<1	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	13	---
Barium	ppm	ASTM D5185m	0	0	---
Molybdenum	ppm	ASTM D5185m	0	0	---
Manganese	ppm	ASTM D5185m	0	<1	---
Magnesium	ppm	ASTM D5185m	0	2	---
Calcium	ppm	ASTM D5185m	2	4	---
Phosphorus	ppm	ASTM D5185m	200	341	---
Zinc	ppm	ASTM D5185m	2	2	---
Sulfur	ppm	ASTM D5185m	16891	16198	---






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1	<1	---
Sodium	ppm	ASTM D5185m	0	<1	---
Potassium	ppm	ASTM D5185m >20	<1	0	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	453	53	---
Particles >6µm	ASTM D7647	>1300	43	10	---
Particles >14µm	ASTM D7647	>160	5	1	---
Particles >21µm	ASTM D7647	>40	1	0	---
Particles >38µm	ASTM D7647	>10	0	0	---
Particles >71µm	ASTM D7647	>3	0	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	16/13/10	13/10/7	---

OIL ANALYSIS REPORT








FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.60	1.075	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual		NEG	NEG	---
Free Water	scalar	*Visual		NEG	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		68.15	69.59	---
Visc @ 100°C	cSt	ASTM D445		10.05	10.21	---
Viscosity Index (VI)	Scale	ASTM D2270		131	131	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						<i>no image</i>
Bottom						<i>no image</i>

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : HPL0003345 **Received** : 14 Apr 2023
Lab Number : 05821215 **Diagnosed** : 19 Apr 2023
Unique Number : 10429298 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: FT-IR, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KENSING
 2525 S KENSINGTON RD
 KANKAKEE, IL
 US 60901
 Contact: TIM HUBERT
 timothy.hubert@kensingolutions.com
 T: (815)939-8918
 F: x: