


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER AS 30 5494800 (S/N 1220)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun2016 Jan2	017 Jul2017 Dec2017 Jun2	018 Feb 2019 Aug 2019 Mar 2022 Sep.	022 Apr2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC110696	KC103121	KC98069
Sample Date		Client Info		03 Apr 2023	08 Sep 2022	01 Mar 2022
Machine Age	hrs	Client Info		35337	32418	29582
Oil Age	hrs	Client Info		2919	1387	2557
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	4	8
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	2	2	1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	3	2
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	388	159	154
Zinc	ppm	ASTM D5185m		245	36	102
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	1	<1
Water	%	ASTM D6304	>0.05	0.004	0.005	0.003
ppm Water	ppm	ASTM D6304	>500	49.1	59.1	25.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		835	2633	17418
Particles >6µm		ASTM D7647	>1300	204	620	▲ 4139
Particles >14μm		ASTM D7647	>80	21	46	△ 369
Particles >21µm		ASTM D7647	>20	8	14	<u>▲</u> 84
Particles >38μm		ASTM D7647	>4	1	0	4 9
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	19/16/13	△ 19/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma K∩H/a	ASTM D8045	1.5	1 15	0.31	0.46

Acid Number (AN)

mg KOH/g ASTM D8045 1.5

1.15

0.31

0.46



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number

Unique Number Test Package

: KC110696 : 05822791 : 10430874 : IND 2

: 18 Apr 2023 Received Diagnosed : 19 Apr 2023

Diagnostician : Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 19567

Contact:

T: F:

WOMELSDORF, PA