




PROBLEM SUMMARY


Area
LTL SILVER P10
 Machine Id
INGERSOLL RAND SSR-EP50SE G6831U98108 - ALL CLAD
 Component
Compressor

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | ATTENTION | SEVERE | ABNORMAL |
|---------------|-----|-----------|--------|----------|
| Visc @ 40°C | cSt | ▲ 103.2 | 45.3 | 45.2 |

Customer Id: UCROCOVER
 Sample No.: UCH05824168
 Lab Number: 05824168
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

14 Nov 2022 Diag: Jonathan Hester

WATER



Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data updates. All component wear rates are normal. There is no indication of any contamination in the oil. Chlorine 0.0 ppm. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



14 Feb 2022 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. Please note that this is a corrected copy for laboratory data updates. All component wear rates are normal. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. Chlorine measured at 15.7 ppm. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



15 Oct 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. Chlorine 0.2 ppm.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area
LTL SILVER P10
 Machine Id
INGERSOLL RAND SSR-EP50SE G6831U98108 - ALL CLAD
 Component
Compressor

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. Chlorine 107 ppm.

Fluid Condition

The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | UCH05824168 | UCH05699078 | UCH05478017 |
| Sample Date | Client Info | | 18 Apr 2023 | 14 Nov 2022 | 14 Feb 2022 |
| Machine Age | hrs | Client Info | 23850 | 23631 | 23089 |
| Oil Age | hrs | Client Info | 219 | 1780 | 1238 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ATTENTION | SEVERE | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|------------|----------|----------|
| Iron | ppm | ASTM D5185m >50 | 0 | <1 | <1 |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >25 | 0 | <1 | <1 |
| Lead | ppm | ASTM D5185m >25 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m >50 | 0 | <1 | <1 |
| Tin | ppm | ASTM D5185m >15 | 0 | <1 | <1 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m 0.1 | 0 | 0 | <1 |
| Barium | ppm | ASTM D5185m 0.8 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m 0 | 0 | 0 | <1 |
| Manganese | ppm | ASTM D5185m 0.9 | <1 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 0 | <1 | 0 | 1 |
| Calcium | ppm | ASTM D5185m 0 | 0 | 0 | 3 |
| Phosphorus | ppm | ASTM D5185m 409 | 48 | 212 | 290 |
| Zinc | ppm | ASTM D5185m 0 | 28 | 19 | 20 |
| Sulfur | ppm | ASTM D5185m 1290 | 240 | 136 | 395 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|------------------|--------|-----------------|------------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | 0 | 0 | 1 |
| Sodium | ppm | ASTM D5185m | 3 | 0 | 0 |
| Potassium | ppm | ASTM D5185m >20 | 0 | 0 | <1 |
| Chlorine Content | ppm | ASTM D5185m | 107 | 0.000 | 15.7 |


FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.537 | 0.18 | 0.23 | 0.26 |




OIL ANALYSIS REPORT

▲ Viscosity @ 40°C



Acid Number







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | MODER |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | 0.2% |
| Free Water | scalar | *Visual | | NEG | 1.0 |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 44.56 ▲ 103.2 | 45.3 | 45.2 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : UCH05824168 **Received** : 19 Apr 2023
Lab Number : 05824168 **Diagnosed** : 25 Apr 2023
Unique Number : 10432251 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: CHLORINEXRF)

ROCKWELL EQUIPMENT & SUPPLY CO
 PO BOX 114
 VERSAILLES, PA
 US 15137
 Contact: DINO PICCOLINO
 DINOP@ROCKWELLEQUIPMENT.COM
 T: (412)824-9903
 F: (412)824-9271

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)