

Machine Id NB-C01B

Component Gearbox

# **PROBLEM SUMMARY**

/20

Oct1/

Aug22/16

Oct18/18

# Sample Rating Trend WATER

# COMPONENT CONDITION SUMMARY Water

Nov13/11

Jun5/14

ROYAL PURPLE SYNERGY 90/220 (--- GAL)

## RECOMMENDATION

0ct21

Mar28/0

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

Sep21/09

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	NORMAL	NORMAL		
Water	%	ASTM D6304	>0.2	<b>A</b> 0.289	0.016	0.007		
ppm Water	ppm	ASTM D6304	>2000	<u> </u>	169.7	77.6		
Debris	scalar	*Visual	NONE	A MODER	NONE	NONE		
Emulsified Water	scalar	*Visual	>0.2	<b>A</b> 0.2%	NEG	NEG		
Free Water	scalar	*Visual		<b>1.0</b>	NEG	NEG		

Customer Id: FORBAT Sample No.: RP0033021 Lab Number: 05826354 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component.			
Check Water Access			?	We advise that you check for the source of water entry.			

### **HISTORICAL DIAGNOSIS**



# 24 Oct 2022 Diag: Don Baldridge

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



# 28 Oct 2021 Diag: Wes Davis



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### 22 Mar 2021 Diag: Wes Davis





Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





# **OIL ANALYSIS REPORT**





# NB-C01B

#### Component Gearbox Fluid BOYAL PURPLE SYNERGY 90/220 (--- GAL

# ROYAL PURPLE SYNERGY 90/220 (--- GAL)

# DIAGNOSIS

### Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

# Wear


All component wear rates are normal.

## Contamination

There is a light concentration of water present in the oil. Free water present.

#### Fluid Condition

The AN level is acceptable for this fluid.



SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0033021	RP0021182	RP0019972
Sample Date		Client Info		05 Apr 2023	24 Oct 2022	28 Oct 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	6	7	3
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	<1	<1	<1
Lead	ppm	ASTM D5185m	>100	0	3	6
Copper	ppm	ASTM D5185m	>200	<1	4	5
Tin	ppm	ASTM D5185m	>25	0	0	0
Antimony	ppm	ASTM D5185m	>5			0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	16
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		17	0	0
Calcium	ppm	ASTM D5185m		3	9	24
Phosphorus	ppm	ASTM D5185m	370	17	84	0
Zinc	ppm	ASTM D5185m		15	124	111
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	0	<1	<1
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>0.2	<b>6</b> 0.289	0.016	0.007
ppm Water	ppm	ASTM D6304	>2000	<b>A</b> 2890	169.7	77.6

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.33	0.36	0.26	0.217




Abnorma


190


180

Oct21/

# **OIL ANALYSIS REPORT**







Bottom

260

240 C240 (201 (40°C) 521 (40°C)

200


180


0ct21


Oct18/18 -

a22/16









Aug22/16

Oct18/18

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Sep21/09

dov13/1

Mar28/D7

Contact/Location: TOMMY ROE - FORBAT