

## **FUEL REPORT**

# KIOTI UW6900154

Component **Diesel Fuel** 

**NOT GIVEN (--- GAL)** 

# Sample Rating Trend



### **DIAGNOSIS**

### Recommendation

We advise that you check for the source of gasoline entry.

### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### ▲ Contaminants

Tests confirm the presence of gasoline in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. The amount and size of particulates present in the system are acceptable.


### ▲ Fuel Condition

The IBP (Initial Boiling Point) is lower than normal. The fuel is no longer serviceable due to the presence of contaminants. Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

			J	Apr2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0000484		
Sample Date		Client Info		19 Apr 2023		
Machine Age	hrs	Client Info		216		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.837		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445		2.3		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		13		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		<u> </u>		
5% Distillation Point	°C	ASTM D86		176		
10% Distill Point	°C	ASTM D86		192		
15% Distillation Point		ASTM D86		202		
20% Distill Point	°C	ASTM D86		210		
30% Distill Point	°C	ASTM D86		225		
40% Distill Point	°C	ASTM D86		239		
50% Distill Point	°C	ASTM D86		254		
60% Distill Point	°C	ASTM D86		268		
70% Distill Point	°C	ASTM D86		284		
80% Distill Point	°C	ASTM D86		301		
85% Distillation Point	°C	ASTM D86		311		
90% Distill Point	°C	ASTM D86		323		
95% Distillation Point	°C	ASTM D86		341		
Final Boiling Point	°C	ASTM D86		347		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.4		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.6		
Cetane Index		ASTM D4737	<40.0	47.8		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	< 0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.005		
ppm Water	ppm	ASTM D6304	< 500	50.8		
% Gasoline	%	*In-House	< 0.50	<u>^</u> 2.6		
% Biodiesel	%	*In-House	<20.0	0.0		



### **FUEL REPORT**







Laboratory Sample No. Lab Number Unique Number

: KT0000484 : 05828211

: 10441704

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 24 Apr 2023 Diagnosed : 27 Apr 2023 Diagnostician : Doug Bogart

Test Package : DF-2 ( Additional Tests: Screen ) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**ALTAVISTA APPLIANCE & SERVICE** 

55 HICKS RD LYNCHBURG, VA US 24502

Contact: WARRANTY warranty@haileys.com T: (434)363-6936

F: