


OIL ANALYSIS REPORT



Machine Id KAESER SFC 55 7180975 (S/N 1024)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb 2021	Aug2021 Jun2022	Oct2022 Jan2023	Apr2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC107711	KC108084	KC107851
Sample Date		Client Info		17 Apr 2023	16 Jan 2023	14 Oct 2022
Machine Age	hrs	Client Info		27700	25563	23514
Oil Age	hrs	Client Info		2200	2000	6413
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	9	11
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	1	1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	28	<1	<1
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		2	3	7
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	2
Sodium	ppm	ASTM D5185m		3	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>0.05	0.014	0.005	0.005
ppm Water	ppm	ASTM D6304	>500	145.7	52.7	58.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		13159	666	2298
Particles >6µm		ASTM D7647	>1300	4039	176	383
Particles >14µm		ASTM D7647	>80	<u>^</u> 295	10	24
Particles >21µm		ASTM D7647	>20	<u>^</u> 69	3	8
Particles >38µm		ASTM D7647	>4	<u>^</u> 6	1	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/15	17/15/10	18/16/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.35

0.35

0.40



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number

: KC107711

: 05828472

Received : 24 Apr 2023 **Tested** : 25 Apr 2023 Diagnosed : 27 Apr 2023 - Jonathan Hester

Unique Number: 10441965 Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - NORHIGKC

US 44143

T: F:

5340 AVION PKWY

HIGHLAND HEIGHTS, OH

Contact: Service Manager