


PROBLEM SUMMARY


UNIT 3 UNIT 3

Component **Reservoir Oil** Fluid **ROYAL PURPLE SYNFILM 32 (--- GAL)**

COMPONENT CONDITION SUMMARY



Sample Rating Trend



WATER

RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	ABNORMAL				
Water	%	ASTM D6304		A 0.425	0.010				
ppm Water	ppm	ASTM D6304		4250	103.1				
Particles >4µm		ASTM D7647	>5000	<u> </u>	<u> </u>				
Particles >6µm		ASTM D7647	>1300	🔺 20601	<u> </u>				
Particles >14µm		ASTM D7647	>160	<u> </u>	▲ 505				
Particles >21µm		ASTM D7647	>40	<u> </u>	🔺 152				
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u> </u>	<u> </u>				
Appearance	scalar	*Visual	NORML	🔺 HAZY	NORML				
Emulsified Water	scalar	*Visual		6.2%	NEG				
Free Water	scalar	*Visual		• 1.0	NEG				

Customer Id: ENEPAT Sample No.: RP0032112 Lab Number: 05829050 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.		

HISTORICAL DIAGNOSIS

02 Jun 2022 Diag: Jonathan Hester



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

WATER

UNIT 3 UNIT 3 Component

Reservoir Oil Fluid ROYAL PURPLE SYNFILM 32 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Free water present. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

			Jun2022	Apr2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0032112	RP0020550	
Sample Date		Client Info		24 Apr 2023	02 Jun 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				SEVERE	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	<1	
Chromium	ppm	ASTM D5185m	>20	0	0	
Nickel	ppm	ASTM D5185m	>20	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	0	<1	
Lead	ppm	ASTM D5185m	>20	0	0	
Copper	ppm	ASTM D5185m	>20	0	0	
Tin	ppm	ASTM D5185m	>20	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	90	10	0	
Calcium	ppm	ASTM D5185m		99	110	
Phosphorus	ppm	ASTM D5185m		439	417	
Zinc	ppm	ASTM D5185m		<1	2	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	4	4	
Sodium	ppm	ASTM D5185m		<1	1	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304		<u> </u>	0.010	
ppm Water	ppm	ASTM D6304		4250	103.1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	A 70183	▲ 11177	
Particles >6µm		ASTM D7647	>1300	<u> </u>	▲ 3398	
Particles >14µm		ASTM D7647	>160	<u> </u>	6 505	
Particles >21µm		ASTM D7647	>40	<u> </u>	1 52	
Particles >38µm		ASTM D7647	>10	5	1 7	
Particles >71µm		ASTM D7647	>3	1	2	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	A 23/22/17	1 /19/16	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.10	0.137	



2 30

204

10 Abn 01

0.1

(mg KOH/g)

Į 0.0 Acid

0.00

38

36

34 24 (J0°C) 25 (40°C)

31

28

26


回音


B

Acid Number

Viscosity @ 40°C

OIL ANALYSIS REPORT





Certificate L2367

Contact/Location: GREG GARRETT - ENEPAT