

Machine Id  
**METSO LINDEMAN METSO BALER M HYD**

Component  
**Hydraulic System**

Fluid  
**AW HYDRAULIC OIL ISO 46 (800 GAL)**

**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>ST44451</b>	ST44832	ST44242
Sample Date	Client Info			<b>21 Apr 2023</b>	19 Jan 2023	22 Aug 2022
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<b>2</b>	2	2
Chromium	ppm	ASTM D5185m	>20	<b>36</b>	38	36
Nickel	ppm	ASTM D5185m	>20	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m	>20	<b>0</b>	<1	0
Copper	ppm	ASTM D5185m	>20	<b>18</b>	20	18
Tin	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	<b>9</b>	10	10
Barium	ppm	ASTM D5185m	5	<b>0</b>	1	0
Molybdenum	ppm	ASTM D5185m	5	<b>3</b>	3	3
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	25	<b>13</b>	11	10
Calcium	ppm	ASTM D5185m	200	<b>92</b>	95	91
Phosphorus	ppm	ASTM D5185m	300	<b>330</b>	326	332
Zinc	ppm	ASTM D5185m	370	<b>400</b>	405	427
Sulfur	ppm	ASTM D5185m	2500	<b>1643</b>	1360	1230

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<b>&lt;1</b>	1	1
Sodium	ppm	ASTM D5185m		<b>3</b>	0	2
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1
Water	%	ASTM D6304	>0.05	<b>0.005</b>	0.020	0.010
ppm Water	ppm	ASTM D6304	>500	<b>57.3</b>	200.1	103.7

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>8064</b>	18903	14998
Particles >6µm		ASTM D7647	>1300	<b>805</b>	▲ 4698	321
Particles >14µm		ASTM D7647	>160	<b>28</b>	▲ 305	36
Particles >21µm		ASTM D7647	>40	<b>9</b>	▲ 51	12
Particles >38µm		ASTM D7647	>10	<b>1</b>	2	1
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/14	<b>20/17/12</b>	▲ 21/19/15	21/16/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.57	<b>0.31</b>	0.33	0.34

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	42.4	42.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : ST44451 **Received** : 26 Apr 2023  
**Lab Number** : 05830716 **Diagnosed** : 28 Apr 2023  
**Unique Number** : 10444209 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF )

**KOBE WIELAND COPPER PRODUCTS**  
 3990 HWY. 311  
 PINE HALL, NC  
 US 27042  
 Contact: NEAL SHINAULT  
 NEAL.SHINAULT@WIELAND.COM  
 T: (336)604-1498  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)