

PROBLEM SUMMARY

NFDM [1718886]


Component **Bearing**


MOBIL SHC 626 (--- QTS)

PT12PP01BB01

Sample Rating Trend WATER

COMPONENT CONDITION SUMMARY





RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | | |
|--------------------------|--------|-------------|------|---------------|--------|----------|--|--|--|
| Sample Status | | | | ABNORMAL | NORMAL | ABNORMAL | | | |
| Phosphorus | ppm | ASTM D5185m | | ^ 202 | 494 | 469 | | | |
| Sulfur | ppm | ASTM D5185m | | 1553 | 24 | 0 | | | |
| Free Water | scalar | *Visual | | 1.0 | NEG | <u> </u> | | | |
| Visc @ 40°C | cSt | ASTM D445 | 69.9 | A 89.0 | 70.7 | 70.9 | | | |

Customer Id: LEPGRE Sample No.: WC0805924 Lab Number: 05833313 Test Package: IND 1



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|--------------------|--------|------|---------|---|
| Water Drain-off | | | ? | We advise that you follow the water drain-off procedure for this component. |
| Check Water Access | | | ? | We advise that you check for the source of water entry. |

HISTORICAL DIAGNOSIS

04 Nov 2022 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.



22 Apr 2022 Diag: Don Baldridge

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.All component wear rates are normal. Free water present. The condition of the oil is acceptable for the time in service.



22 Oct 2021 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend


WATER

NFDM [1718886] Machine Id PT12PP01BB01

Component

Bearing

MOBIL SHC 626 (--- QTS)



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Free water present.

Fluid Condition


The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirm oil type.

| | | Feb 2019 Oct | 2019 Apr2020 Oct2020 | May2021 Oct2021 Apr2022 Nov20 | 22 Apr2023 | |
|------------------|--------|--------------|----------------------|-------------------------------|-------------|----------------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | WC0805924 | WC0745803 | WC0693957 |
| Sample Date | | Client Info | | 22 Apr 2023 | 04 Nov 2022 | 22 Apr 2022 |
| Machine Age | hrs | Client Info | | 1 | 1 | 1 |
| Oil Age | hrs | Client Info | | 1 | 1 | 1 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | ABNORMAL | NORMAL | ABNORMAL |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >20 | 3 | 2 | <1 |
| Chromium | ppm | ASTM D5185m | >20 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >20 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >20 | 0 | <1 | <1 |
| Lead | ppm | ASTM D5185m | >20 | 0 | 0 | <1 |
| Copper | ppm | | >20 | 7 | <1 | 0 |
| Tin | ppm | ASTM D5185m | >20 | 0 | <1 | 0 |
| Antimony | ppm | ASTM D5185m | - | | | |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| | PPIII | | | - | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | | 1 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | | 2 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | <u> </u> | 494 | 469 |
| Zinc | ppm | ASTM D5185m | | 93 | 3 | 0 |
| Sulfur | ppm | ASTM D5185m | | △ 1553 | 24 | 0 |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >15 | 0 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | <1 |
| Water | % | ASTM D6304 | >2 | 0.045 | | 0.085 |
| ppm Water | ppm | ASTM D6304 | | 450 | | 850 |
| VISUAL | | method | limit/base | current | history1 | history2 |
| White Metal | scalar | *Visual | NONE | LIGHT | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >2 | 0.2% | NEG | 0.2% |
| Free Water | scalar | *Visual | | <u> </u> | NEG | ▲ 1.0 |
| 7:55:35) Ray: 1 | Juanan | | | | | I VII I ASENOR |

Submitted By: MICHAEL VILLASENOR



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number Unique Number : 10446806

: WC0805924 : 05833313

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 28 Apr 2023 : 02 May 2023

Diagnostician : Doug Bogart Test Package : IND 1 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

EKLINE@LEPRINOFOODS.COM T:

LEPRINO FOODS-GREELEY

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (970)347-5190

Contact: ERIC KLINE

1302 1ST AVE

GREELEY, CO

US 80631-5909