

FUEL REPORT

Sample Rating Trend





{not provided} (--- GAL)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

				Mar2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0798116		
Sample Date		Client Info		23 Mar 2023		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
	LITTLO		IIIIII Dase		History	
Specific Gravity	4 4	*ASTM D1298		0.842		
Fuel Color	text	*Visual Screen		Orang		
ASTM Color	scalar	*ASTM D1500		L1.5		
Visc @ 40°C	cSt	ASTM D445		2.42		
Pensky-Martens Flash Point	°C	*PMCC Calculated		57		
SULFUR CONTER	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		13		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		160		
5% Distillation Point	°C	ASTM D86		189		
10% Distill Point	°C	ASTM D86		199		
15% Distillation Point	°C	ASTM D86		210		
20% Distill Point	°C	ASTM D86		218		
30% Distill Point	°C	ASTM D86		232		
40% Distill Point	°C	ASTM D86		247		
50% Distill Point	°C	ASTM D86		261		
60% Distill Point	°C	ASTM D86		275		
70% Distill Point	°C	ASTM D86		290		
80% Distill Point	°C	ASTM D86		307		
85% Distillation Point	°C	ASTM D86		317		
90% Distill Point	°C	ASTM D86		327		
95% Distillation Point	°C	ASTM D86		342		
Final Boiling Point	°C	ASTM D86		350		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.2		
			limit/booo		historyd	hiotom/0
IGNITION QUALIT		method	limit/base		history1	history2
API Gravity		ASTM D7777	40.0	36.6		
Cetane Index		ASTM D4737	<40.0	47.8		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.005		
ppm Water	ppm	ASTM D6304	<500	52.5		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	2.8		



FUEL REPORT





Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: WC0798116 : 05833358 : 10446851

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 28 Apr 2023 Diagnosed : 12 May 2023 Diagnostician : Doug Bogart

Test Package: DF-2 (Additional Tests: BACTERIA, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KB POWER SYSTEMS LLC

738 Old Buies Creek Rd Lillington, NC US 27546

Contact: DWAYNE REGISTER

dwayne@kbpowersystemsnc.com T: (919)577-9136

Contact/Location: DWAYNE REGISTER - KBPHOL

Report Id: KBPHOL [WUSCAR] 05833358 (Generated: 01/16/2024 13:49:20) Rev: 1

F: