



FUEL REPORT

Sample Rating Trend



ISO



Machine Id
SIS 25 - 4520 BUNNLEVEL ERWIN RD

Component
Diesel Fuel
Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Recommend pre-filtering before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0798109	---	---
Sample Date	Client Info	06 Mar 2023	---	---
Machine Age	hrs Client Info	0	---	---
Sample Status		ABNORMAL	---	---

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.837	---	---
Fuel Color	text *Visual Screen	Pink	---	---
ASTM Color	scalar *ASTM D1500	L3.5	---	---
Visc @ 40°C	cSt ASTM D445	2.46	---	---
Pensky-Martens Flash Point	°C *PMCC Calculated	58	---	---

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm ASTM D5185m	0	---	---
Sulfur (UVF)	ppm ASTM D5453	9	---	---

DISTILLATION

method	limit/base	current	history1	history2
Initial Boiling Point	°C ASTM D86	162	---	---
5% Distillation Point	°C ASTM D86	187	---	---
10% Distill Point	°C ASTM D86	199	---	---
15% Distillation Point	°C ASTM D86	208	---	---
20% Distill Point	°C ASTM D86	215	---	---
30% Distill Point	°C ASTM D86	229	---	---
40% Distill Point	°C ASTM D86	244	---	---
50% Distill Point	°C ASTM D86	257	---	---
60% Distill Point	°C ASTM D86	272	---	---
70% Distill Point	°C ASTM D86	287	---	---
80% Distill Point	°C ASTM D86	304	---	---
85% Distillation Point	°C ASTM D86	314	---	---
90% Distill Point	°C ASTM D86	326	---	---
95% Distillation Point	°C ASTM D86	344	---	---
Final Boiling Point	°C ASTM D86	353	---	---
Distillation Residue	% ASTM D86	1.4	---	---
Distillation Loss	% ASTM D86	0.8	---	---

IGNITION QUALITY

method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.6	---	---
Cetane Index	ASTM D4737 <40.0	48.8	---	---


CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m <1.0	0	---	---
Sodium	ppm ASTM D5185m <0.1	0	---	---
Potassium	ppm ASTM D5185m <0.1	0	---	---
Water	% ASTM D6304 <0.05	0.003	---	---
ppm Water	ppm ASTM D6304 <500	33.5	---	---
% Gasoline	% *In-House <0.50	0.0	---	---
% Biodiesel	% *In-House <20.0	0.0	---	---




FUEL REPORT


Particle Count




Particle Trend



Water (KF)



Viscosity @ 40°C



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 25318	---	---
Particles >6µm	ASTM D7647	>640	▲ 8750	---	---
Particles >14µm	ASTM D7647	>80	▲ 511	---	---
Particles >21µm	ASTM D7647	>20	▲ 79	---	---
Particles >38µm	ASTM D7647	>4	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 22/20/16	---	---


HEAVY METALS	method	limit/base	current	history1	history2	
Aluminum	ppm	ASTM D5185m	<0.1	0	---	---
Nickel	ppm	ASTM D5185m	<0.1	0	---	---
Lead	ppm	ASTM D5185m	<0.1	0	---	---
Vanadium	ppm	ASTM D5185m	<0.1	0	---	---
Iron	ppm	ASTM D5185m	<0.1	0	---	---
Calcium	ppm	ASTM D5185m	<0.1	0	---	---
Magnesium	ppm	ASTM D5185m	<0.1	0	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	---	---
Zinc	ppm	ASTM D5185m	<0.1	0	---	---

SAMPLE IMAGES


	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS


Fuel Distillation Curve



Pensky-Martens Flash Point (°C)



Fuel Distillation Curve



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0798109 **Received** : 28 Apr 2023
Lab Number : 05833366 **Diagnosed** : 09 May 2023
Unique Number : 10446859 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KB POWER SYSTEMS LLC
 738 Old Buies Creek Rd
 Lillington, NC
 US 27546

Contact: DWAYNE REGISTER
 dwayne@kbpowersystemsnc.com

T: (919)577-9136

F: