

FUEL REPORT

Sample Rating Trend

VISUAL METAL

SLS 142 - 1811 ERWIN RD

Diesel Fuel

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you inspect for the source(s) of rust.

Corrosion

Moderate concentration of visible metal present as rust.

Contaminants

There is a moderate amount of visible silt present in the sample. There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible.


Fuel Condition


Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.


				Mar2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0798121		
Sample Date		Client Info		08 Mar 2023		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.842		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L5.5		
Visc @ 40°C	cSt	ASTM D445		2.5		
Pensky-Martens Flash Point	°C	*PMCC Calculated		58		
SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		10		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		163		
5% Distillation Point	°C	ASTM D86		188		
10% Distill Point	°C	ASTM D86		200		
15% Distillation Point	°C	ASTM D86		209		
20% Distill Point	°C	ASTM D86		217		
30% Distill Point	°C	ASTM D86		232		
40% Distill Point	°C	ASTM D86		246		
50% Distill Point	°C	ASTM D86		261		
60% Distill Point	°C	ASTM D86		276		
70% Distill Point	°C	ASTM D86		291		
80% Distill Point	°C	ASTM D86		308		
85% Distillation Point	°C	ASTM D86		317		
90% Distill Point	°C	ASTM D86		328		
95% Distillation Point	°C	ASTM D86		343		
Final Boiling Point	°C	ASTM D86		351		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.6		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.6		
Cetane Index		ASTM D4737	<40.0	47.9		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.006		
ppm Water	ppm	ASTM D6304	<500	67.4		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	1.9		



FUEL REPORT







MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	0		
Yeast	CFU/ml	WC-Method	>=100000	0		
Mold	Colonies	WC-Method	MODER			
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	<0.1	0		
Vanadium	ppm	ASTM D5185m	<0.1	0		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	0		
Magnesium	ppm	ASTM D5185m	<0.1	0		
Phosphorus	ppm	ASTM D5185m	<0.1	0		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGES	5	method	limit/base	current	history1	history2


70

Color





GRAPHS

Bottom



Pensky-Martens Flash Point (°C)







Test Package : DF-2 (Additional Tests: BACTERIA, Screen) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Recieved

Diagnosed

: WC0798121

: 05833374

Laboratory Sample No.

Lab Number

Unique Number : 10446867

Contact/Location: DWAYNE REGISTER - KBPHOL