




FUEL REPORT

Sample Rating Trend

VIS DEBRIS



Machine Id
EC1
 Component
Diesel Fuel
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

Corrosion

All metal levels are normal indicating no corrosion in the system.

▲ Contaminants

Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|----------|----------|
| Sample Number | Client Info | | | WC0798118 | --- | --- |
| Sample Date | Client Info | | | 30 Apr 2023 | --- | --- |
| Machine Age | hrs | Client Info | | 0 | --- | --- |
| Sample Status | | | | ABNORMAL | --- | --- |

| PHYSICAL PROPERTIES | | method | limit/base | current | history1 | history2 |
|----------------------------|--------|------------------|------------|--------------|----------|----------|
| Specific Gravity | | *ASTM D1298 | | 0.844 | --- | --- |
| Fuel Color | text | *Visual Screen | | Red | --- | --- |
| ASTM Color | scalar | *ASTM D1500 | | L4.0 | --- | --- |
| Visc @ 40°C | cSt | ASTM D445 | | 2.57 | --- | --- |
| Pensky-Martens Flash Point | °C | *PMCC Calculated | | 58 | --- | --- |

| SULFUR CONTENT | | method | limit/base | current | history1 | history2 |
|----------------|-----|-------------|------------|------------|----------|----------|
| Sulfur | ppm | ASTM D5185m | | 0 | --- | --- |
| Sulfur (UVF) | ppm | ASTM D5453 | | 210 | --- | --- |




| DISTILLATION | | method | limit/base | current | history1 | history2 |
|------------------------|----|----------|------------|------------|----------|----------|
| Initial Boiling Point | °C | ASTM D86 | | 161 | --- | --- |
| 5% Distillation Point | °C | ASTM D86 | | 190 | --- | --- |
| 10% Distill Point | °C | ASTM D86 | | 201 | --- | --- |
| 15% Distillation Point | °C | ASTM D86 | | 211 | --- | --- |
| 20% Distill Point | °C | ASTM D86 | | 219 | --- | --- |
| 30% Distill Point | °C | ASTM D86 | | 233 | --- | --- |
| 40% Distill Point | °C | ASTM D86 | | 247 | --- | --- |
| 50% Distill Point | °C | ASTM D86 | | 261 | --- | --- |
| 60% Distill Point | °C | ASTM D86 | | 275 | --- | --- |
| 70% Distill Point | °C | ASTM D86 | | 290 | --- | --- |
| 80% Distill Point | °C | ASTM D86 | | 306 | --- | --- |
| 85% Distillation Point | °C | ASTM D86 | | 316 | --- | --- |
| 90% Distill Point | °C | ASTM D86 | | 326 | --- | --- |
| 95% Distillation Point | °C | ASTM D86 | | 342 | --- | --- |
| Final Boiling Point | °C | ASTM D86 | | 348 | --- | --- |
| Distillation Residue | % | ASTM D86 | | 1.4 | --- | --- |
| Distillation Loss | % | ASTM D86 | | 0.4 | --- | --- |

| IGNITION QUALITY | | method | limit/base | current | history1 | history2 |
|------------------|--|------------|------------|-------------|----------|----------|
| API Gravity | | ASTM D7777 | | 36.2 | --- | --- |
| Cetane Index | | ASTM D4737 | <40.0 | 47.0 | --- | --- |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | <1.0 | 0 | --- | --- |
| Sodium | ppm | ASTM D5185m | <0.1 | 0 | --- | --- |
| Potassium | ppm | ASTM D5185m | <0.1 | 0 | --- | --- |
| Water | % | ASTM D6304 | <0.05 | 0.005 | --- | --- |
| ppm Water | ppm | ASTM D6304 | <500 | 53.2 | --- | --- |
| % Gasoline | % | *In-House | <0.50 | 0.0 | --- | --- |
| % Biodiesel | % | *In-House | <20.0 | 1.4 | --- | --- |



FUEL REPORT





| MICROBIAL | method | limit/base | current | history1 | history2 |
|-----------|--------------------|------------|----------|----------|----------|
| Bacteria | CFU/ml WC-Method | >=100000 | 0 | --- | --- |
| Yeast | CFU/ml WC-Method | >=100000 | 0 | --- | --- |
| Mold | Colonies WC-Method | MODER | --- | --- | --- |

| HEAVY METALS | method | limit/base | current | history1 | history2 |
|--------------|-----------------|------------|----------|----------|----------|
| Aluminum | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Nickel | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Lead | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Vanadium | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Iron | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Calcium | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Magnesium | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Phosphorus | ppm ASTM D5185m | <0.1 | 0 | --- | --- |
| Zinc | ppm ASTM D5185m | <0.1 | 0 | --- | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

| | | | | | |
|--------|--|--|--|----------|----------|
| Color | | | | no image | no image |
| Bottom | | | | no image | no image |

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0798118 **Received** : 28 Apr 2023
Lab Number : 05833377 **Diagnosed** : 12 May 2023
Unique Number : 10446870 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: BACTERIA, Screen)

KB POWER SYSTEMS LLC
 738 Old Buies Creek Rd
 Lillington, NC
 US 27546
 Contact: DWAYNE REGISTER
 dwayne@kbpowersystemsnc.com
 T: (919)577-9136
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)