



# FUEL REPORT

Sample Rating Trend



ISO



Machine Id  
**833 - PARMELE UNIT 1**

Component  
**Diesel Fuel**  
Fluid  
**{not provided} (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

Recommend pre-filtering before use. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### ▲ Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0798138</b>	---	---
Sample Date	Client Info			<b>11 Apr 2023</b>	---	---
Machine Age	hrs	Client Info		<b>0</b>	---	---
Sample Status				<b>ABNORMAL</b>	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		<b>0.846</b>	---	---
Fuel Color	text	*Visual Screen		<b>Red</b>	---	---
ASTM Color	scalar	*ASTM D1500		<b>L4.5</b>	---	---
Visc @ 40°C	cSt	ASTM D445		<b>2.57</b>	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		<b>65</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		<b>0</b>	---	---
Sulfur (UVF)	ppm	ASTM D5453		<b>182</b>	---	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		<b>176</b>	---	---
5% Distillation Point	°C	ASTM D86		<b>198</b>	---	---
10% Distill Point	°C	ASTM D86		<b>207</b>	---	---
15% Distillation Point	°C	ASTM D86		<b>216</b>	---	---
20% Distill Point	°C	ASTM D86		<b>222</b>	---	---
30% Distill Point	°C	ASTM D86		<b>236</b>	---	---
40% Distill Point	°C	ASTM D86		<b>250</b>	---	---
50% Distill Point	°C	ASTM D86		<b>264</b>	---	---
60% Distill Point	°C	ASTM D86		<b>278</b>	---	---
70% Distill Point	°C	ASTM D86		<b>293</b>	---	---
80% Distill Point	°C	ASTM D86		<b>308</b>	---	---
85% Distillation Point	°C	ASTM D86		<b>318</b>	---	---
90% Distill Point	°C	ASTM D86		<b>328</b>	---	---
95% Distillation Point	°C	ASTM D86		<b>343</b>	---	---
Final Boiling Point	°C	ASTM D86		<b>351</b>	---	---
Distillation Residue	%	ASTM D86		<b>1.4</b>	---	---
Distillation Loss	%	ASTM D86		<b>0.8</b>	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		<b>35.8</b>	---	---
Cetane Index		ASTM D4737	<40.0	<b>47.3</b>	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.005</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>56.2</b>	---	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	%	*In-House	<20.0	<b>2.1</b>	---	---



# FUEL REPORT





FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 6460	---	---
Particles >6µm	ASTM D7647	>640	▲ 2586	---	---
Particles >14µm	ASTM D7647	>80	▲ 335	---	---
Particles >21µm	ASTM D7647	>20	▲ 101	---	---
Particles >38µm	ASTM D7647	>4	2	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/19/16	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	---
Nickel	ppm	ASTM D5185m	<0.1	0	---
Lead	ppm	ASTM D5185m	<0.1	0	---
Vanadium	ppm	ASTM D5185m	<0.1	0	---
Iron	ppm	ASTM D5185m	<0.1	0	---
Calcium	ppm	ASTM D5185m	<0.1	0	---
Magnesium	ppm	ASTM D5185m	<0.1	0	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	---
Zinc	ppm	ASTM D5185m	<0.1	0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0798138      **Received** : 28 Apr 2023  
**Lab Number** : 05833382      **Tested** : 10 May 2023  
**Unique Number** : 10446875      **Diagnosed** : 12 May 2023 - Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: Screen )  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**KB POWER SYSTEMS LLC**  
 738 Old Buies Creek Rd  
 Lillington, NC  
 US 27546  
 Contact: DWAYNE REGISTER  
 dwayne@kbpowersystemsnc.com  
 T: (919)577-9136  
 F: