

FUEL REPORT

ODT

Sample Rating Trend





Machine Id SLS 44 Component Diesel Fuel Fluid

DIESEL FUEL No. 1 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

			1	Mar2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0798095		
Sample Date		Client Info		07 Mar 2023		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	FRTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.842		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445	2.4	2.53		
Pensky-Martens Flash Point	°C	*PMCC Calculated	2.7	58		
•						
SULFUR CONTE	NI	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		15		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		161		
5% Distillation Point	°C	ASTM D86		187		
10% Distill Point	°C	ASTM D86		198		
15% Distillation Point	°C	ASTM D86		208		
20% Distill Point	°C	ASTM D86		217		
30% Distill Point	°C	ASTM D86		232		
40% Distill Point	°C	ASTM D86		247		
50% Distill Point	°C	ASTM D86		261		
60% Distill Point	°C	ASTM D86		276		
70% Distill Point	°C	ASTM D86		291		
80% Distill Point	°C	ASTM D86		308		
85% Distillation Point	°C	ASTM D86		318		
90% Distill Point	°C	ASTM D86		329		
95% Distillation Point	°C	ASTM D86		347		
Final Boiling Point	°C	ASTM D86		350		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		1.5		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.6		
Cetane Index		ASTM D4737	<40.0	47.8		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.006		
ppm Water	ppm	ASTM D6304	<500	61.0		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	1.6		



FUEL REPORT





Laboratory Sample No. Lab Number Unique Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 05833392

: WC0798095 : 10446885

Recieved Diagnosed

: 12 May 2023 Diagnostician : Doug Bogart

: 28 Apr 2023

Test Package: DF-2 (Additional Tests: BACTERIA, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

738 Old Buies Creek Rd Lillington, NC US 27546

KB POWER SYSTEMS LLC

Contact: DWAYNE REGISTER dwayne@kbpowersystemsnc.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T: (919)577-9136 F: