


# PROBLEM SUMMARY


Area  
**OCC AND PULP**  
 Machine Id  
**421.0555 ID FAN DRIVE SIDE**  
 Component  
**Gearbox**  
 Fluid  
**SHELL MORLINA S4 B 68 (--- GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. Inspect/change air breather if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	---
Particles >4µm	ASTM D7647	>20000	▲ <b>214535</b>	▲ 215149	---
Particles >6µm	ASTM D7647	>5000	▲ <b>88662</b>	▲ 162681	---
Particles >14µm	ASTM D7647	>640	▲ <b>1345</b>	▲ 14997	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>25/24/18</b>	▲ 25/25/21	---

Customer Id: PORPORWA  
 Sample No.: PE0000872  
 Lab Number: 05835130  
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS

06 Dec 2022 Diag: Jonathan Hester

### WEAR




We recommend you service the filters on this component. We recommend an early resample to monitor this condition. The lead level is abnormal. Bearing and/or bushing wear is indicated. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area  
**OCC AND PULP**  
 Machine Id  
**421.0555 ID FAN DRIVE SIDE**  
 Component  
**Gearbox**  
 Fluid  
**SHELL MORLINA S4 B 68 (--- GAL)**



## DIAGNOSIS

### ▲ Recommendation

Check seals and/or filters for points of contaminant entry. Inspect/change air breather if applicable. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PE0000872</b>	PE0000871	---
Sample Date	Client Info	<b>21 Apr 2023</b>	06 Dec 2022	---
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	---
Sample Status		<b>ABNORMAL</b>	ABNORMAL	---

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	<b>22</b>	37	---
Iron	ppm	ASTM D5185m	>200	<b>16</b>
Chromium	ppm	ASTM D5185m	>15	<b>0</b>
Nickel	ppm	ASTM D5185m	>15	<b>0</b>
Titanium	ppm	ASTM D5185m		<b>0</b>
Silver	ppm	ASTM D5185m		<b>0</b>
Aluminum	ppm	ASTM D5185m	>25	<b>0</b>
Lead	ppm	ASTM D5185m	>100	<b>0</b>
Copper	ppm	ASTM D5185m	>200	<b>10</b>
Tin	ppm	ASTM D5185m	>25	<b>&lt;1</b>
Vanadium	ppm	ASTM D5185m		<b>0</b>
Cadmium	ppm	ASTM D5185m		<b>0</b>

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>
Barium	ppm	ASTM D5185m		<b>0</b>
Molybdenum	ppm	ASTM D5185m		<b>0</b>
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>
Magnesium	ppm	ASTM D5185m		<b>2</b>
Calcium	ppm	ASTM D5185m		<b>27</b>
Phosphorus	ppm	ASTM D5185m		<b>280</b>
Zinc	ppm	ASTM D5185m		<b>18</b>
Sulfur	ppm	ASTM D5185m		<b>622</b>





## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<b>54</b>
Sodium	ppm	ASTM D5185m		<b>4</b>
Potassium	ppm	ASTM D5185m	>20	<b>0</b>

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>▲ 214535</b>	▲ 215149
Particles >6µm	ASTM D7647	>5000	<b>▲ 88662</b>	▲ 162681
Particles >14µm	ASTM D7647	>640	<b>▲ 1345</b>	▲ 14997
Particles >21µm	ASTM D7647	>160	<b>196</b>	▲ 785
Particles >38µm	ASTM D7647	>40	<b>5</b>	13
Particles >71µm	ASTM D7647	>10	<b>0</b>	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 25/24/18</b>	▲ 25/25/21

# OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.68</b>	0.64	---



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	---
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	---
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	---
Free Water	scalar	*Visual		<b>NEG</b>	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	<b>72.4</b>	71.9	---

### SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				
Bottom				

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PE0000872 **Received** : 02 May 2023  
**Lab Number** : **05835130** **Diagnosed** : 04 May 2023  
**Unique Number** : 10453933 **Diagnostician** : Angela Borella  
**Test Package** : PLANT ( Additional Tests: ICP, KV40, PQ, PrtCount, SCREEN )

**Port Townsend Paper Corporation**  
 100 Mill Rd  
 Port Townsend, WA  
 US 98368  
 Contact: LONNIE LOREE  
 lonnie.loree@ptpc.com  
 T: (907)738-6506  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)