

PROBLEM SUMMARY

Sample Rating Trend

WATER

Machine Id


WEBSTER ALPHA RAIL HOT OIL HEATER (S/N 118734A-01)


Component


Heat Transfer Fluid

TULCO LUBSOIL HEAT TRANSFER 250 (--- GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ATTENTION
Water	%	ASTM D6304	>0.0601	△ 0.561	0.031	
ppm Water	ppm	ASTM D6304	>601	<u>▲</u> 5610	318.9	
Silt	scalar	*Visual	NONE	▲ HEAVY	▲ HEAVY	NONE
Visc @ 40°C	cSt	ASTM D445	52	4 247	△ 329	△ 76.3
Visc @ 100°C	cSt	ASTM D445	7.5	28.3	▲ 53.2	<u>▲</u> 10.5

Customer Id: BLUMUSOK Sample No.: TO10001843 Lab Number: 05837746 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS Action Date Done By Description **Status** We advise that you perform a filter service, and use off-line filtration to Change Filter ? improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of Alert ? particles present in this sample. We advise that you perform a filter service, and use off-line filtration to ? Filter Fluid improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

06 Feb 2020 Diag: Doug Bogart

VISCOSITY



Resample at the next service interval to monitor. Please note that this is a corrected copy for data entry updates. All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend

WATER

WEBSTER ALPHA RAIL HOT OIL HEATER (S/N 118734A-01)

Heat Transfer Fluid

TULCO LUBSOIL HEAT TRANSFER 250 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of visible silt present in the sample. There is a moderate concentration of water present in the fluid.


Fluid Condition


An increase in the AN level is noted. The AN level is acceptable for this fluid.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO10001843	TO10000668	TO1002082
Sample Date		Client Info		20 Mar 2023	23 Nov 2021	06 Feb 2020
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	160	167	60
Chromium	ppm	ASTM D5185m	>21	0	<1	0
Nickel	ppm	ASTM D5185m	>21	0	0	0
Titanium	ppm	ASTM D5185m	>21	0	0	0
Silver	ppm	ASTM D5185m	>21	0	0	<1
Aluminum	ppm	ASTM D5185m	>21	<1	<1	1
Lead	ppm	ASTM D5185m	>21	0	0	<1
Copper	ppm	ASTM D5185m	>21	0	0	0
Tin	ppm	ASTM D5185m	>21	1	<1	<1
Antimony	ppm	ASTM D5185m	>21		0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		2	1	<1
Magnesium	ppm	ASTM D5185m		4	0	<1
Calcium	ppm	ASTM D5185m		2	3	7
Phosphorus	ppm	ASTM D5185m		4	44	5
Zinc	ppm	ASTM D5185m		0	0	4
Sulfur	ppm	ASTM D5185m	1400	455	652	997
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	3
Sodium	ppm	ASTM D5185m	>21	2	1	3
Potassium	ppm	ASTM D5185m	>20	1	0	<1
Water	%	ASTM D6304	>0.0601	<u> </u>	0.031	
ppm Water	ppm	ASTM D6304	>601	<u>▲</u> 5610	318.9	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	1.595	0.06	0.569




OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ HEAVY	▲ HEAVY	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.0601	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	52	<u> </u>	▲ 329	△ 76.3
Visc @ 100°C	cSt	ASTM D445	7.5	28.3	▲ 53.2	△ 10.5
Viscosity Index (VI)	Scale	ASTM D2270	106	150	228	122

limit/base

current

history1


method

GRAPHS

Color

Bottom

SAMPLE IMAGES







Certificate L2367

Laboratory Sample No. Lab Number

Unique Number : 10456549

: TO10001843 : 05837746

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed Diagnostician : Doug Bogart

: 04 May 2023 : 10 May 2023

Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

MUSKOGEE, OK Contact: COLE HOWELL

Donovan.Howell@ergon.com T:

ERGON - CALLERY - ALPHA - BETA - DELTA

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (918)683-6061

2501 PORT PL

US 74403

history2