




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
RIG 879
 Machine Id
R879-P-02-NKL
 Component
Pump
 Fluid
GEAR OIL ISO 320 (--- GAL)

DIAGNOSIS

Recommendation

The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0012424	KL0009707	---
Sample Date	Client Info		01 May 2023	19 Apr 2023	---
Machine Age	days	Client Info	45047	45035	---
Oil Age	days	Client Info	0	0	---
Oil Changed	Client Info		Changed	Not Chngd	---
Sample Status			ABNORMAL	SEVERE	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	13	43	---
Chromium	ppm	ASTM D5185m >7	0	0	---
Nickel	ppm	ASTM D5185m	0	0	---
Titanium	ppm	ASTM D5185m	0	0	---
Silver	ppm	ASTM D5185m	0	0	---
Aluminum	ppm	ASTM D5185m >25	<1	3	---
Lead	ppm	ASTM D5185m >35	0	0	---
Copper	ppm	ASTM D5185m >50	<1	2	---
Tin	ppm	ASTM D5185m >5	0	0	---
Vanadium	ppm	ASTM D5185m	0	0	---
Cadmium	ppm	ASTM D5185m	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 50	19	1	---
Barium	ppm	ASTM D5185m 15	0	10	---
Molybdenum	ppm	ASTM D5185m 15	10	55	---
Manganese	ppm	ASTM D5185m	<1	<1	---
Magnesium	ppm	ASTM D5185m 50	18	8	---
Calcium	ppm	ASTM D5185m 50	57	250	---
Phosphorus	ppm	ASTM D5185m 350	194	177	---
Zinc	ppm	ASTM D5185m 100	25	70	---
Sulfur	ppm	ASTM D5185m 12500	10227	13486	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	8	19	---
Sodium	ppm	ASTM D5185m	36	45	---
Potassium	ppm	ASTM D5185m >20	1	1	---

FLUID CLEANLINESS




	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		170561	---	---
Particles >6µm	ASTM D7647	>1300	▲ 66481	---	---
Particles >14µm	ASTM D7647	>160	▲ 2660	---	---
Particles >21µm	ASTM D7647	>40	▲ 487	---	---
Particles >38µm	ASTM D7647	>10	9	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>17/14	▲ 23/19	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	0.35	0.26	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ HEAVY	---
Debris	scalar	*Visual	NONE	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	▲ MILKY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	NEG	● 0.2%	---
Free Water	scalar	*Visual	NEG	▲ 1.0	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	325	312	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0012424 **Received** : 05 May 2023
Lab Number : 05839200 **Diagnosed** : 08 May 2023
Unique Number : 10458003 **Diagnostician** : Doug Bogart
Test Package : MOB 2 (Additional Tests: PrtCount)

PATTERSON - UTI DRILLING
 9915 WEST INDUSTRIAL
 MIDLAND, TX
 US 79706
 Contact: MICHEAL EASTMAN
 micheal.eastman@patenergy.com
 T: (325)716-8686
 F: (432)561-9388

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)