


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7478838

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May202	1 0ct2021	May2022 M	ay2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP53294	KCP45498	KCP39364
Sample Date		Client Info		02 May 2023	02 May 2022	15 Oct 2021
Machine Age	hrs	Client Info		853	816	815
Oil Age	hrs	Client Info		853	400	100
Oil Changed		Client Info		Not Changd	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	<1
Barium	ppm	ASTM D5185m	90	75	83	60
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	83	86	70
Calcium	ppm	ASTM D5185m	0	0	3	<1
Phosphorus	ppm	ASTM D5185m	0	4	6	3
Zinc	ppm	ASTM D5185m	0	0	2	0
Sulfur	ppm	ASTM D5185m	23500	22429	14626	14661
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		5	<1	0
Potassium	ppm	ASTM D5185m	>20	<1	2	<1
Water	%	ASTM D6304		0.018	0.027	0.042
ppm Water	ppm	ASTM D6304	>500	182.2	276.5	426.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8843	4356	4177
Particles >6µm		ASTM D7647	>1300	A 3000	<u> </u>	884
Particles >14μm		ASTM D7647	>80	<u> </u>	56	30
Particles >21μm		ASTM D7647	>20	<u>^</u> 23	14	6
Particles >38μm		ASTM D7647	>4	1	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/15	19/18/13	17/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: KCP53294 : 05840732 Unique Number : 10459535

Received **Tested** Diagnosed

Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 08 May 2023 : 10 May 2023 : 10 May 2023 - Doug Bogart

FEDEX 145 PINNACLE DR ROMEOVILLE, IL US 60446 Contact: CYNTHIA GEORGE CYNTHIA.GEORGE@FEDEX.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: