



FUEL REPORT

Sample Rating Trend



WATER



Machine Id
NW MILFORD DPW

Component
Gasoline

Fluid
NOT GIVEN (--- QTS)

DIAGNOSIS

▲ Recommendation

This is a baseline read-out on the submitted sample.

▲ Contamination

There is a light concentration of water present in the gasoline.

SAMPLE INFORMATION

method	limit/base	current	history 1	history 2
Sample Number	Client Info	WC0814949	---	---
Sample Date	Client Info	07 May 2023	---	---
Machine Age	hrs	Client Info	0	---
Oil Age	hrs	Client Info	0	---
Oil Changed	Client Info	N/A	---	---
Sample Status		ABNORMAL	---	---



PHYSICAL PROPERTIES

method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	0.5	---

CONTAMINANTS

method	limit/base	current	history 1	history 2	
Water	%	ASTM D6304	<0.05	▲ 0.134	---
ppm Water	ppm	ASTM D6304	<500	▲ 1343.9	---
% Gasoline	%	*In-House	<0.50	87.0	---
% Biodiesel	%	*In-House	<20.0	0.0	---





SAMPLE IMAGES

method	limit/base	current	history 1	history 2
Color			no image	no image
Bottom			no image	no image



FUEL REPORT

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0814949 **Received** : 08 May 2023
Lab Number : 05841126 **Diagnosed** : 16 May 2023
Unique Number : 10459929 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: API, CC Flash, Cetane, Color-ASTM, Fuel, GC-PercFuel, ICP, KF, KV40, PriCou

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Weber Oil Company
 601 Industrial Road
 Carlstadt, NJ
 US 07072
 Contact: IAN WELLS
 ian@weberoil.com
 T:
 F: (201)438-3178