

PROBLEM SUMMARY

Sample Rating Trend

WATER




2000040824 (S/N 8552139)

Component

Screw Compressor

TULCO LUBSOIL SYNTHETIC COMPRESSOR 46 (5 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS									
Sample Status				ABNORMAL					
Water	%	ASTM D6304	>0.1	<u> </u>					
ppm Water	ppm	ASTM D6304	>1000	1620					
Debris	scalar	*Visual	NONE	▲ MODER					
Free Water	scalar	*\/icual		A 1 0					

Customer Id: CITOKLOK Sample No.: TO20000172 Lab Number: 05841417 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.		
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.		

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Machine Id

2000040824 (S/N 8552139)

Componen

Screw Compressor

TULCO LUBSOIL SYNTHETIC COMPRESSOR 46 (5 GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

				Apr2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO20000172		
Sample Date		Client Info		25 Apr 2023		
Machine Age	hrs	Client Info		55		
Oil Age	hrs	Client Info		55		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>60	<1		
Chromium	ppm	ASTM D5185m	>4	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>5	<1		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>30	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m	74	813		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m	1000	0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	3		
Water	%	ASTM D6304	>0.1	△ 0.162		
ppm Water	ppm	ASTM D6304	>1000	▲ 1620		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.135


Acid Number (AN)

mg KOH/g ASTM D8045 0.236

Contact/Location: MITCHEL LOGAN - CITOKLOK



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number

Unique Number

: 05841417 : 10460220

: TO20000172

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 08 May 2023 Diagnosed : 12 May 2023

Diagnostician : Jonathan Hester Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CITY OF OKC - SE WATER

500 W MAIN ST, SUITE 100 OKLAHOMA CITY, OK US 73102

Contact: MITCHEL LOGAN

T:

F: