


OIL ANALYSIS REPORT

Sample Rating Trend



WATER



163 Bryant

Component

Compressor

Compressor Oil (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

Free water present.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Pe0202	3 Mat2023	Aprizoza W	ay2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		AO0000339	WC0781831	WC0781803
Sample Date		Client Info		04 May 2023	05 Apr 2023	02 Mar 2023
Machine Age	hrs	Client Info		38205	37519	36708
Oil Age	hrs	Client Info		2976	2260	1464
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	<1
Lead	ppm	ASTM D5185m	>25	<1	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	<1
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		16	9	8
Calcium	ppm	ASTM D5185m		1306	1263	1188
Phosphorus	ppm	ASTM D5185m		297	287	263
Zinc	ppm	ASTM D5185m		348	323	301
Sulfur	ppm	ASTM D5185m		1509	1615	1520
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	<1
Sodium	ppm	ASTM D5185m		<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	5	<1	<1
Water	%	ASTM D6304	>0.1	0.092		
ppm Water	ppm	ASTM D6304	>1000	920		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
				Current		
Acid Number (AN)	mg KOH/g	ASTM D8045		0.351	0.42	0.144



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: AO0000339

: 05845671 : 10469778 Recieved : 12 May 2023 Diagnosed

: 16 May 2023 Diagnostician : Angela Borella

Test Package : MOB 2 (Additional Tests: FuelDilution, KF, PercentFuel, TBN) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PO BOX 472 SEMINOLE, OK US 74818

Contact: Dylan Jackson djackson@enerfin.com

T: (405)382-3049 F: (405)382-6716