




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
131 Lexington 1
 Component
Natural Gas Engine
 Fluid
IPP LA 6000X (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0781880	WC0781928	WC0781855
Sample Date	Client Info		05 May 2023	06 Apr 2023	02 Mar 2023
Machine Age	hrs	Client Info	6079	5417	4599
Oil Age	hrs	Client Info	2952	2160	1506
Oil Changed		Client Info	N/A	N/A	N/A
Sample Status			NORMAL	MARGINAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	4	5	4
Chromium	ppm	ASTM D5185m >4	<1	<1	<1
Nickel	ppm	ASTM D5185m >2	<1	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	2	2	1
Lead	ppm	ASTM D5185m >30	1	0	0
Copper	ppm	ASTM D5185m >35	0	<1	<1
Tin	ppm	ASTM D5185m >4	<1	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	<1	<1	<1
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	12	5	2
Calcium	ppm	ASTM D5185m 1267	1623	1462	1337
Phosphorus	ppm	ASTM D5185m 300	346	300	275
Zinc	ppm	ASTM D5185m 330	421	360	329
Sulfur	ppm	ASTM D5185m	1224	1207	1121

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	1	<1	1
Sodium	ppm	ASTM D5185m	1	<1	<1
Potassium	ppm	ASTM D5185m >20	5	<1	1
Fuel	%	ASTM D3524 >4.0	0.5	▲ 2.2	1.3

INFRA-RED





	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0.1
Nitration	Abs/cm	*ASTM D7624 >20	9.8	8.5	7.5
Sulfation	Abs/.1mm	*ASTM D7415 >30	16.5	14.1	14.6

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	13.1	11.4	10.1
Acid Number (AN)	mg KOH/g	ASTM D8045	1.12	1.10	0.87
Base Number (BN)	mg KOH/g	ASTM D2896 4.8	3.67	4.98	4.76











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445 14	14.0	13.9	13.6

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0781880 **Received** : 12 May 2023
Lab Number : 05845710 **Diagnosed** : 15 May 2023
Unique Number : 10469817 **Diagnostician** : Wes Davis
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

ENERFIN GATHERING
 1103 S S&W ROAD
 DUNCAN, OK
 US 73533
 Contact: Luis Colmenares
 lcolmenares@enerfin.com
 T: (405)268-1927
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)