

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO

Machine Id


# KAESER BSD 60 4808356 (S/N 1016)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST	RESULTS				
Sample Status			ATTENTION	ABNORMAL	NORMAL
Particles >6µm	ASTM D7647	>1300	<b>1836</b>	<b>4977</b>	692
Particles >14μm	ASTM D7647	>80	<b>147</b>	<u>^</u> 262	72
Particles >21µm	ASTM D7647	>20	<b>4</b> 1	<u></u> 54	21
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/18/14</b>	<u> </u>	17/13

Customer Id: NORTRUKC Sample No.: KC107795 Lab Number: 05849770 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

## 14 Apr 2022 Diag: Angela Borella

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 12 Oct 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 26 Oct 2020 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# KAESER BSD 60 4808356 (S/N 1016)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS**

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jec2013 Jul	2014 May2015 Aug201	16 Aug2017 Jun2019 Oct20	21 May202:	
SAMPLE INFORM	<b>MATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC107795	KC103242	KC98503
Sample Date		Client Info		08 May 2023	14 Apr 2022	12 Oct 2021
Machine Age	hrs	Client Info		70977	61692	57283
Oil Age	hrs	Client Info		4316	4409	6016
Oil Changed		Client Info		Not Changd	Not Changd	Changed
Sample Status				ATTENTION	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	5	8	12
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	2	1	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		<1	7	<1
Zinc	ppm	ASTM D5185m		0	4	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	1	<1
Water	%	ASTM D6304	>0.05	0.006	0.004	0.009
ppm Water	ppm	ASTM D6304	>500	64.1	42.0	92.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5810	18887	2683
Particles >6µm		ASTM D7647	>1300	<b>1836</b>	<b>4977</b>	692
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>^</u> 262	72
Particles >21µm		ASTM D7647	>20	<u></u> 41	<b>△</b> 54	21
Particles >38µm		ASTM D7647	>4	1	1	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14	<b>△</b> 19/15	17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
		4STM D8045		0.40	0.38	0.360

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.38

0.40

0.360



## OIL ANALYSIS REPORT



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact:

T: F: