




# PROBLEM SUMMARY

Sample Rating Trend



**WATER**



Machine Id  
**KAESER AIR TOWER 5C 8434498 (S/N 1422)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	---	---
Water	%	ASTM D6304	>0.05	<b>▲ 0.198</b>	---	---
ppm Water	ppm	ASTM D6304	>500	<b>▲ 1980</b>	---	---
Particles >14µm		ASTM D7647	>80	<b>▲ 151</b>	---	---
Particles >21µm		ASTM D7647	>20	<b>▲ 51</b>	---	---
Particles >38µm		ASTM D7647	>4	<b>▲ 8</b>	---	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	<b>▲ 18/17/14</b>	---	---
Appearance	scalar	*Visual	NORML	<b>▲ HAZY</b>	---	---
Free Water	scalar	*Visual		<b>▲ 1.0</b>	---	---

Customer Id: USGSTP  
 Sample No.: KC102751  
 Lab Number: 05850202  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS


Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS



# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER AIR TOWER 5C 8434498 (S/N 1422)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### ▲ Contamination

Appearance is hazy. There is a moderate amount of particulates present in the oil. Free water present. There is a light concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC102751</b>	---	---
Sample Date	Client Info	<b>08 May 2023</b>	---	---
Machine Age	hrs Client Info	<b>136</b>	---	---
Oil Age	hrs Client Info	<b>3</b>	---	---
Oil Changed	Client Info	<b>N/A</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>50	<b>2</b>	---	---
Chromium ppm ASTM D5185m	>10	<b>0</b>	---	---
Nickel ppm ASTM D5185m	>3	<b>0</b>	---	---
Titanium ppm ASTM D5185m	>3	<b>0</b>	---	---
Silver ppm ASTM D5185m	>2	<b>0</b>	---	---
Aluminum ppm ASTM D5185m	>10	<b>0</b>	---	---
Lead ppm ASTM D5185m	>10	<b>0</b>	---	---
Copper ppm ASTM D5185m	>50	<b>0</b>	---	---
Tin ppm ASTM D5185m	>10	<b>0</b>	---	---
Vanadium ppm ASTM D5185m		<b>0</b>	---	---
Cadmium ppm ASTM D5185m		<b>0</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m	0	<b>0</b>	---	---
Barium ppm ASTM D5185m	90	<b>24</b>	---	---
Molybdenum ppm ASTM D5185m	0	<b>0</b>	---	---
Manganese ppm ASTM D5185m		<b>&lt;1</b>	---	---
Magnesium ppm ASTM D5185m	100	<b>44</b>	---	---
Calcium ppm ASTM D5185m	0	<b>0</b>	---	---
Phosphorus ppm ASTM D5185m	0	<b>4</b>	---	---
Zinc ppm ASTM D5185m	0	<b>0</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>25	<b>0</b>	---	---
Sodium ppm ASTM D5185m		<b>3</b>	---	---
Potassium ppm ASTM D5185m	>20	<b>1</b>	---	---
Water % ASTM D6304	>0.05	<b>▲ 0.198</b>	---	---
ppm Water ppm ASTM D6304	>500	<b>▲ 1980</b>	---	---




## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm ASTM D7647		<b>1627</b>	---	---
Particles >6µm ASTM D7647	>1300	<b>886</b>	---	---
Particles >14µm ASTM D7647	>80	<b>▲ 151</b>	---	---
Particles >21µm ASTM D7647	>20	<b>▲ 51</b>	---	---
Particles >38µm ASTM D7647	>4	<b>▲ 8</b>	---	---
Particles >71µm ASTM D7647	>3	<b>1</b>	---	---
Oil Cleanliness ISO 4406 (c)	>--/17/13	<b>▲ 18/17/14</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D8045	1.0	<b>0.31</b>	---	---


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	▲ HAZY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	0.2%	---
Free Water	scalar	*Visual		▲ 1.0	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	43.5	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC102751 **Received** : 17 May 2023  
**Lab Number** : 05850202 **Diagnosed** : 22 May 2023  
**Unique Number** : 10479557 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2

**US GEOLOGICAL SURVEY**  
 600 4TH ST N  
 ST PETE, FL  
 US 33701  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: