


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER SFC 37T 5673724 (S/N 1061)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | KC101232 | KC82190 | KC90426 |
| Sample Date | Client Info | | 15 May 2023 | 22 Mar 2022 | 05 May 2021 |
| Machine Age | hrs | Client Info | 29138 | 23828 | 19199 |
| Oil Age | hrs | Client Info | 5310 | 4629 | 6200 |
| Oil Changed | Client Info | | Changed | Changed | Changed |
| Sample Status | | | NORMAL | NORMAL | NORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >50 | 0 | 0 | 0 |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m >10 | <1 | <1 | 0 |
| Lead | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m >50 | 13 | 7 | 9 |
| Tin | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|----------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | <1 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 90 | 4 | 0 | 2 |
| Calcium | ppm | ASTM D5185m 2 | 0 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 3 | 6 | 19 |
| Zinc | ppm | ASTM D5185m | 78 | 89 | 67 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | 3 | 3 | 3 |
| Sodium | ppm | ASTM D5185m | 1 | <1 | 0 |
| Potassium | ppm | ASTM D5185m >20 | <1 | 0 | 0 |
| Water | % | ASTM D6304 >0.05 | 0.003 | 0.004 | 0.008 |
| ppm Water | ppm | ASTM D6304 >500 | 32.0 | 40.9 | 82.7 |






FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|------------------|------------|-----------------|----------|----------|
| Particles >4µm | ASTM D7647 | | 2581 | 2628 | 1626 |
| Particles >6µm | ASTM D7647 >1300 | | 513 | 618 | 556 |
| Particles >14µm | ASTM D7647 >80 | | 15 | 46 | 34 |
| Particles >21µm | ASTM D7647 >20 | | 3 | 13 | 9 |
| Particles >38µm | ASTM D7647 >4 | | 0 | 0 | 0 |
| Particles >71µm | ASTM D7647 >3 | | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >--/17/13 | 19/16/11 | 16/13 | 16/12 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|----------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.4 | 0.44 | 0.46 | 0.431 |


OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | LIGHT |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | 44.6 | 44.3 | 44.4 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC101232 **Received** : 18 May 2023
Lab Number : 05851284 **Diagnosed** : 23 May 2023
Unique Number : 10480639 **Diagnostician** : Jonathan Hester
Test Package : IND 2

LAUREN AGRIS SYSTEMS - COOPER STANDARD
 2162 REISER AVE SE
 NEW PHILADELPHIA, OH
 US 44663
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: