


COOLANT REPORT

DAKOTA RANGE III [200006928] 19WEA87754 - D-02-A

Coolant

CLARIANT ANTIFROGEN N (--- LTR)





Recommendation

The fluid is suitable for further service.

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX010396		
Sample Date		Client Info		04 May 2023		
Machine Age	hrs	Client Info		14344		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	S method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	1.11	1.067		
рН	Scale 0-14	ASTM D1287	8.5	8.04		
Nitrites	ppm	AP-053:2009		184		
Reserve Alkalinity	Scale 0-20	*ASTM D1121	4.0			
Percentage Glycol	%	ASTM D3321	44	49.8		
Freezing Point	°F	ASTM D3321	-32	-33		
Total Dissolved Solids				277.0		
Carboxylate				n/a		
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	3	9		
Phosphorus	ppm	ASTM D6130	5	51		
Boron	ppm	ASTM D6130	15	21		
Molybdenum	ppm	ASTM D6130	110	272		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	2		
Aluminum	ppm	ASTM D6130	>10	1		
Copper	ppm	ASTM D6130	>10	1		
Lead	ppm	ASTM D6130	>10	<1		
Tin	ppm	ASTM D6130	>10	1		
Zinc	ppm	ASTM D6130		1		
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		38		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130	2400	5343		
Potassium	ppm	ASTM D6130	5	165		
SCALE POTENTI	AL _	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		<1		
Magnesium	ppm	ASTM D6130		1		
	PP					



COOLANT REPORT









Laboratory Sample No.

: NX010396 Lab Number : 05852671 Unique Number : 10482026

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 **Tested**

Received : 19 May 2023 : 26 May 2023 Diagnosed : 26 May 2023 - Jonathan Hester

NORDEX USA - Chicago 300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL US 60606

Certificate 12367

Test Package : COOL- (Additional Tests: COOL, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: DEVIN LINEHAN DLinehan@nordex-online.com T: (312)386-4124

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (312)386-7102 Contact/Location: DEVIN LINEHAN - NORDEX