


# **COOLANT REPORT**

# **DAKOTA RANGE III [200006928]** 24WEA87746 - E-02-A

Coolant

**CLARIANT ANTIFROGEN N (--- LTR)** 





### Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

#### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.


#### **Coolant Condition**

The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.


SAMPLE INFORM	MATIO <u>N</u>	method	limit/base	current	history1	history2
Sample Number		Client Info		NX05852719		
Sample Date		Client Info		12 Apr 2023		
Machine Age	hrs	Client Info		14741		
Oil Age	hrs	Client Info		0		
Oil Changed	1110	Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST F	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	1.11	1.067		
oH	Scale 0-14	ASTM D1287	8.5	8.20		
Vitrites	ppm	AP-053:2009	0.0	72		
Reserve Alkalinity	Scale 0-20	*ASTM D1121	4.0			
Percentage Glycol	%	ASTM D3321	4.0	49.8		
Freezing Point	°F	ASTM D3321	-32	-33		
Total Dissolved Solids	1	7.0 1101 00021	UL.	278.0		
Carboxylate				n/a		
CORROSION INH	IRITORS	method	limit/base	current	history1	history2
Silicon		ASTM D6130	3	11		
Phosphorus	ppm	ASTM D6130	5	60		
Boron	ppm	ASTM D6130	15	20		
Molybdenum	ppm	ASTM D6130	110	322		
	ppiii					
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	29		
Aluminum	ppm	ASTM D6130	>10	6		
Copper	ppm	ASTM D6130	>10	1		
Lead	ppm	ASTM D6130	>10	<1		
Tin	ppm	ASTM D6130	>10	2		
Zinc	ppm	ASTM D6130		4		
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		38		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130	2400	5219		
Potassium	ppm	ASTM D6130	5	369		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		1		
Magnesium	ppm	ASTM D6130		2		



## **COOLANT REPORT**











Certificate 12367

Laboratory Sample No.

: NX05852719 Lab Number : 05852719 Unique Number : 10482074

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 19 May 2023 **Tested** : 26 May 2023 : 04 Jun 2023 - Doug Bogart Diagnosed

**NORDEX USA - Chicago** 300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL US 60606 Contact: DEVIN LINEHAN DLinehan@nordex-online.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : COOL- (Additional Tests: COOL, ICP)

T: (312)386-4124 F: (312)386-7102

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: NORDEX [WUSCAR] 05852719 (Generated: 05/03/2024 11:46:19) Rev: 1

Contact/Location: DEVIN LINEHAN - NORDEX