


OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



KAESER 1133 EAST

Component

Compressor

KAESER SIGMA (OEM) M-460 (8 GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

			Nov2015	May2023		
SAMPLE INFORM	AATIONI	ام مالم مما		· · · · · · · · · · · · · · · · · · ·	la i a ka m . 4	history O
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC100910	WCI2279739	
Sample Date		Client Info		15 May 2023	03 Nov 2015	
Machine Age	hrs	Client Info		25197	5859	
Oil Age	hrs	Client Info		2500	2268	
Oil Changed		Client Info		Changed	Changed	
Sample Status				MARGINAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	6	8	
Tin	ppm	ASTM D5185m	>10	<1	0	
Antimony	ppm	ASTM D5185m	>10		0	
Vanadium		ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
	ppm	ASTIVI DOTOSIII		U	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	31	8	
Molybdenum	ppm	ASTM D5185m	0	0	<1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	58	35	
Calcium	ppm	ASTM D5185m	0	15	0	
Phosphorus	ppm	ASTM D5185m	0	13	1	
Zinc	ppm	ASTM D5185m	0	80	12	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	
Sodium	ppm	ASTM D5185m		19	12	
Potassium	ppm	ASTM D5185m	>20	3	16	
Water	%	ASTM D6304	>0.05	0.017		
ppm Water	ppm	ASTM D6304	>500			
				178.1		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
FLUID CLEANLIN Particles >4µm	IESS	method ASTM D7647				history2
	IESS		limit/base	current	history1	
Particles >4μm	IESS	ASTM D7647	limit/base	current 1617	history1	
Particles >4μm Particles >6μm	IESS	ASTM D7647 ASTM D7647	limit/base >1300	current 1617 507	history1	
Particles >4µm Particles >6µm Particles >14µm	IESS	ASTM D7647 ASTM D7647 ASTM D7647	limit/base	current 1617 507 43	history1	
Particles >4µm Particles >6µm Particles >14µm Particles >21µm	IESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4	current 1617 507 43 9	history1	
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm	IESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4	current 1617 507 43 9 1	history1	
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm Oil Cleanliness		ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ISO 4406 (c)	Simit/base Sim	current 1617 507 43 9 1 0 16/13	history1	
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm		ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	Simit/base Sim	current 1617 507 43 9 1	history1	



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: KC100910 : 05853240

: 10482595 Test Package : IND 2

Recieved : 22 May 2023

Diagnosed : 25 May 2023 : Jonathan Hester Diagnostician

43650 OBERLIN-ELYRIA RD OBERLIN, OH

US 44014 Contact: LEWIE

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (440)536-0009 F: