

FUEL REPORT

Sample Rating Trend

NORMAL

LAWNWOOD SPLIT CONVAULT

Component

AL)

Diesei	Fuei	
Fluid		
DDSL	(2000	GA

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no Bacteria, Yeast and/or Fungus indicated in the sample. There is no indication of any contamination in the fuel.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

			Apr2022	May2023		
SAMPLE INFORM	MOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		WC05854743	WCDF04641	
Sample Date		Client Info		16 May 2023	28 Apr 2022	
Machine Age	mls	Client Info		0	0	
Sample Status				NORMAL	NORMAL	
PHYSICAL PROP	FRTIFS	method	limit/base	current	history1	history2
Specific Gravity	0	*ASTM D1298		0.840	0.845	
Fuel Color	text	*Visual Screen		Red	Red	
ASTM Color	scalar	*ASTM D1500		L4.5	L5.5	
				2.57		
Visc @ 40°C	cSt	ASTM D445			2.5	
Pensky-Martens Flash Point	°C	*PMCC Calculated		58	60	
Cloud Point	°C	ASTM D5771		-11	-12	
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0	2	
Sulfur (UVF)	ppm	ASTM D5453		8	7	
DISTILLATION		method	limit/base	current	history1	history2
	۰.۰	ASTM D86	mmbase		· ·	
Initial Boiling Point	°C			161	162	
5% Distillation Point	°C	ASTM D86		190	191	
10% Distill Point	°C	ASTM D86		203	203	
15% Distillation Point	°C	ASTM D86		212	211	
20% Distill Point	°C	ASTM D86		220	220	
30% Distill Point	°C	ASTM D86		234	235	
40% Distill Point	°C	ASTM D86		248	248	
50% Distill Point	°C	ASTM D86		262	262	
60% Distill Point	°C	ASTM D86		277	275	
70% Distill Point	°C	ASTM D86		291	290	
80% Distill Point	°C	ASTM D86		307	306	
85% Distillation Point	°C	ASTM D86		317	315	
90% Distill Point	°C	ASTM D86		328	327	
95% Distillation Point	°C	ASTM D86		345	343	
Final Boiling Point	°C	ASTM D86		352	352	
Distillation Residue	%	ASTM D86		1.4	1.4	
Distillation Loss	%	ASTM D86		1.0	0.7	
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.0	36.0	
Cetane Index		ASTM D4737	<40.0	49.0	47.1	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	
Sodium	ppm	ASTM D5185m	<0.1	0	0	
Potassium		ASTM D5185m	<0.1	<1	0	
Water	ppm %	ASTM D5165111	<0.1	0.003	0.004	
		ASTM D6304 ASTM D6304		39.7		
ppm Water % Gasoline	ppm o/	*In-House	<500		41.5	
% Gasonne	%	III-HOUSE	< 0.50	0.0	0.0	

% Biodiesel


0.0

0.0

*In-House <20.0



FUEL REPORT





Laboratory Sample No. Lab Number Unique Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 05854743

: WC05854743 : 10484098

Received : 23 May 2023 Diagnosed Diagnostician : Aaron Black

: 30 May 2023 Test Package : DF-2 (Additional Tests: CldPt, Screen)

Contact: WENDALL STRODERD

wendall@tankwizards.com T: (321)427-5149

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TANK WIZARDS

F: (321)574-4131

PALM BAY, FL

US 32907

1511 MASTERS RD NW