




PROBLEM SUMMARY

Sample Rating Trend



ADDITIVES




Area
BEEBE [2005316]
 Machine Id
20WEA82323

Component
Wind Turbine Gearbox
 Fluid
CASTROL OPTIGEAR SYNTHETIC X 320 (4 LTR)

COMPONENT CONDITION SUMMARY

▲ Additives



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Molybdenum	ppm	ASTM D5185m	1150	▲ 40	825	754
Calcium	ppm	ASTM D5185m	2000	▲ 83	1691	1554
Sulfur	ppm	ASTM D5185m	1850	▲ 5910	1912	1662

Customer Id: NORBEE
 Sample No.: NX010893
 Lab Number: 05855497
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

19 May 2022 Diag: Angela Borella

WEAR



We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Gear wear is indicated. The high ferrous density (PQ) index indicates that abnormal wear is occurring. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.

view report



10 Oct 2021 Diag: Jonathan Hester

WEAR



We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Gear wear is indicated. The high ferrous density (PQ) index indicates that abnormal wear is occurring. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.

view report



20 Aug 2021 Diag: Jonathan Hester

WEAR



We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Gear wear is indicated. The high ferrous density (PQ) index indicates that abnormal wear is occurring. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area
BEEBE [2005316]
 Machine Id
20WEA82323

Component
Wind Turbine Gearbox
 Fluid
CASTROL OPTIGEAR SYNTHETIC X 320 (4 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		NX010893	NX05568728	NX005745
Sample Date	Client Info		22 May 2023	19 May 2022	10 Oct 2021
Machine Age	hrs	Client Info	94444	79572	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2	
PQ	ASTM D8184	>80	16	▲ 111	▲ 109	
Iron	ppm	ASTM D5185m	>150	23	▲ 396	▲ 373
Chromium	ppm	ASTM D5185m	>5	<1	4	4
Nickel	ppm	ASTM D5185m	>10	<1	<1	2
Titanium	ppm	ASTM D5185m	>10	0	0	0
Silver	ppm	ASTM D5185m		0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	<1
Copper	ppm	ASTM D5185m	>50	0	3	2
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m	>5	---	---	0
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	<1

ADDITIVES

	method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185m		2	21	<1
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m	1150	▲ 40	825	754
Manganese	ppm	ASTM D5185m		<1	4	3
Magnesium	ppm	ASTM D5185m		2	23	24
Calcium	ppm	ASTM D5185m	2000	▲ 83	1691	1554
Phosphorus	ppm	ASTM D5185m	400	228	368	331
Zinc	ppm	ASTM D5185m	0	0	8	7
Sulfur	ppm	ASTM D5185m	1850	▲ 5910	1912	1662

CONTAMINANTS






	method	limit/base	current	history 1	history 2	
Silicon	ppm	ASTM D5185m	>50	2	11	8
Sodium	ppm	ASTM D5185m	>20	2	7	6
Potassium	ppm	ASTM D5185m	>20	3	0	<1
Water	%	ASTM D6304	>0.05	0.008	0.028	0.025
ppm Water	ppm	ASTM D6304	>500	89.6	287.2	251.5

FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		23424	7405	36667
Particles >6µm	ASTM D7647	>2500	1153	1394	1751
Particles >14µm	ASTM D7647	>320	29	75	16
Particles >21µm	ASTM D7647	>80	7	13	3
Particles >38µm	ASTM D7647	>20	1	0	0
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	22/17/12	20/18/13	22/18/11



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.6	0.25	0.33	0.343






VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	320	330	306	292.9

SAMPLE IMAGES		method	limit/base	current	history 1	history 2
---------------	--	--------	------------	---------	-----------	-----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : NX010893 **Received** : 24 May 2023
Lab Number : 05855497 **Diagnosed** : 05 Jun 2023
Unique Number : 10484852 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

NORDEX USA - BEEBE
 1200 S COUNTY FARM RD
 ITHACA, MI
 US 48847
 Contact: TUCKER WITT
 tucker.witt@constellation.com
 T:
 F: (312)386-7102

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)