




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**RIG 879**  
 Machine Id  
**R879-P-03**  
 Component  
**Pump Drive**  
 Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2	
Sample Number	Client Info	<b>KL0012216</b>	KL0012427	KL0012421	
Sample Date	Client Info	<b>23 May 2023</b>	01 May 2023	26 Apr 2023	
Machine Age	days	Client Info	<b>45069</b>	45047	45042
Oil Age	days	Client Info	<b>0</b>	15	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A	
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL	

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >500	<b>11</b>	13	8
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>4</b>	2	0
Lead	ppm	ASTM D5185m	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >35	<b>1</b>	<1	<1
Tin	ppm	ASTM D5185m >4	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>1</b>	0	0
Barium	ppm	ASTM D5185m	<b>2</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>9</b>	9	7
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>7</b>	5	4
Calcium	ppm	ASTM D5185m	<b>439</b>	496	512
Phosphorus	ppm	ASTM D5185m	<b>48</b>	40	31
Zinc	ppm	ASTM D5185m	<b>18</b>	4	15
Sulfur	ppm	ASTM D5185m	<b>10402</b>	9969	8742

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >75	<b>13</b>	12	9
Sodium	ppm	ASTM D5185m	<b>24</b>	44	48
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	1

## FLUID CLEANLINESS





method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>134567</b>	108461	77673
Particles >6µm	ASTM D7647 >5000	<b>▲ 25768</b>	▲ 20216	▲ 10967
Particles >14µm	ASTM D7647 >640	<b>154</b>	194	64
Particles >21µm	ASTM D7647 >160	<b>8</b>	21	7
Particles >38µm	ASTM D7647 >40	<b>0</b>	0	0
Particles >71µm	ASTM D7647 >10	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >19/16	<b>▲ 22/14</b>	▲ 22/15	▲ 21/13

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.71</b>	0.096	0.157




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>LIGHT</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>312</b>	313	310

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0012216 **Received** : 25 May 2023  
**Lab Number** : 05857191 **Diagnosed** : 26 May 2023  
**Unique Number** : 10486546 **Diagnostician** : Doug Bogart  
**Test Package** : MOB 2 ( Additional Tests: PrtCount )

**PATTERSON - UTI DRILLING**  
 9915 WEST INDUSTRIAL  
 MIDLAND, TX  
 US 79706  
 Contact: MICHEAL EASTMAN  
 micheal.eastman@patenergy.com  
 T: (325)716-8686  
 F: (432)561-9388

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)