

# **PROBLEM SUMMARY**


Area 3

WINERGY GEARBOX WTG-304 (S/N 4834518-0020-1)

**Wind Turbine Gearbox** 

**FUCHS RENOLIN UNISYN CKC ISO 320 (340 LTR)** 

**COMPONENT CONDITION SUMMARY** 



No relevant graphs to display

# RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC 1	TEST RE	SULTS				
Sample Status				<b>ABNORMAL</b>	NORMAL	ABNORMAL
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE	▲ MODER

Customer Id: ENEFRA **Sample No.:** WC0804478 Lab Number: 05857923 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

# HISTORICAL DIAGNOSIS

### 27 Jan 2022 Diag: Aaron Black

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. Analytical ferrography: wear is normal with typical amounts of ferrous rubbing wear. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Analytical ferrography: contamination is normal with typical amounts of external debris present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



# 06 Mar 2021 Diag: Doug Bogart

SEDIMENT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# view report

# 26 Jul 2020 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The condition of the oil is suitable for further service.






# **OIL ANALYSIS REPORT**

# WINERGY GEARBOX WTG-304 (S/N 4834518-0020-1)

**Wind Turbine Gearbox** 

**FUCHS RENOLIN UNISYN CKC ISO 320 (340 LTR)** 





# **DIAGNOSIS**

## Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

# Wear

All component wear rates are normal.

## Contamination

There is a high amount of visible silt present in the sample.


# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

io Eiii,		Vov2013 Sep	2014 Feb2016 Apr201	7 Jul2018 Oct2019 Mar20	21 Mar202:	
SAMPLE INFORMA	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0804478	WC05504537	WC0547165
Sample Date		Client Info		02 Mar 2023	27 Jan 2022	06 Mar 2021
Machine Age	mths	Client Info		94	78	120
Oil Age	mths	Client Info		94	0	65
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>50	14	17	17
Iron	ppm	ASTM D5185m	>65	11	17	12
Chromium	ppm	ASTM D5185m	>3	0	<1	<1
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>10	0	0	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>10	1	<1	0
	ppm	ASTM D5185m	>5	0	<1	0
	ppm	ASTM D5185m	>10	0	<1	<1
	ppm	ASTM D5185m	>10	<1	0	<1
	ppm	ASTM D5185m	>5			0
Vanadium	ppm	ASTM D5185m		0	0	0
	ppm	ASTM D5185m		0	0	0
	PP		11 1.4			
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	25	<1	0	3
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m	17	6	10	6
Phosphorus	ppm	ASTM D5185m	200	112	133	132
Zinc	ppm	ASTM D5185m		4	29	0
Sulfur	ppm	ASTM D5185m	5000	4047	3138	3102
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	0
Sodium	ppm	ASTM D5185m		2	0	1
Potassium	ppm	ASTM D5185m	>20	1	0	<1
Water	%	ASTM D6304	>0.03	0.009	0.005	0.020
ppm Water	ppm	ASTM D6304	>300	97.7	51.2	208.1
FLUID CLEANLINE	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			968	
Particles >6µm		ASTM D7647	>5000		117	
Particles >14µm		ASTM D7647	>640		11	
Particles >21µm		ASTM D7647	>160		3	
Particles >38µm		ASTM D7647	>40		0	
Particles >71µm		ASTM D7647	>10		0	
Oil Cleanliness		ISO 4406 (c)	>/19/16		17/14/11	



# OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0804478

: 05857923 : 10492388

Received Diagnosed

: 26 May 2023 : 30 May 2023 Diagnostician : Don Baldridge

**Test Package**: IND 2 (Additional Tests: KF, PQ, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **ENERGIA EOLICA** 

STA ANA KM25 CARRETERA AL SUR, A 1KM DEL CRUCE FRANCISCO MORAZAN, ZZ

HN Contact: SANTOS DEL CID

sdelcid@dencmi.com

T: x: F: x:

Report Id: ENEFRA [WUSCAR] 05857923 (Generated: 10/24/2023 10:46:50) Rev: 1

Contact/Location: SANTOS DEL CID - ENEFRA