




PROBLEM SUMMARY

Sample Rating Trend



WEAR



Area

2

Machine Id

WINERGY GEARBOX WTG-201 (S/N 4836486-0020-3)

Component


Wind Turbine Gearbox

Fluid


FUCHS RENOLIN UNISYN CKC ISO 320 (340 LTR)

COMPONENT CONDITION SUMMARY

▲ Ferrous Alloys



▲ Viscosity @ 40°C



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ATTENTION	
Iron	ppm	ASTM D5185m >65	▲ 104	▲ 90	64
Visc @ 40°C	cSt	ASTM D445 315	▲ 170	▲ 189.5	▲ 209

Customer Id: ENEFRA
 Sample No.: WC0804477
 Lab Number: 05857924
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

WEAR



26 Jan 2022 Diag: Aaron Black

We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. Analytical ferrography: Normal amounts of wear debris are present with typical amounts of ferrous rubbing wear on the ferrogram. Moderate concentration of visible dirt/debris present in the oil. Analytical ferrography: Elevated amounts of contamination appear to be present. Without a corresponding elevated amount of wear debris, this is suspected to be due to sample contamination rather than equipment ingress, or the particulate is too soft to damage the components. Viscosity of sample indicates oil is within ISO 220 range, advise investigate. The AN level is acceptable for this fluid.

view report



VISCOSITY



01 Mar 2021 Diag: Don Baldrige

Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 220 range, advise investigate. The AN level is acceptable for this fluid.

view report



VISCOSITY



24 Jul 2020 Diag: Doug Bogart

Resample at the next service interval to monitor. All ferrographic tests and evaluation performed at WC Canada laboratory. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 220 range, advise investigate. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area

2

Machine Id

WINERGY GEARBOX WTG-201 (S/N 4836486-0020-3)

Component

Wind Turbine Gearbox

Fluid

FUCHS RENOLIN UNISYN CKC ISO 320 (340 LTR)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

▲ Wear

Gear wear is indicated. All other component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

▲ Fluid Condition

The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0804477	WC05504532	WC0547140
Sample Date	Client Info		22 Feb 2023	26 Jan 2022	01 Mar 2021
Machine Age	mths	Client Info	89	74	120
Oil Age	mths	Client Info	89	0	65
Oil Changed	Client Info		N/A	N/A	Not Changd
Sample Status			ABNORMAL	ABNORMAL	ATTENTION

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184	>50	17	16	21
Iron	ppm	ASTM D5185m	>65	▲ 104	▲ 90
Chromium	ppm	ASTM D5185m	>3	3	2
Nickel	ppm	ASTM D5185m	>3	0	<1
Titanium	ppm	ASTM D5185m	>10	0	0
Silver	ppm	ASTM D5185m		0	<1
Aluminum	ppm	ASTM D5185m	>10	1	<1
Lead	ppm	ASTM D5185m	>5	0	0
Copper	ppm	ASTM D5185m	>10	3	3
Tin	ppm	ASTM D5185m	>10	<1	0
Antimony	ppm	ASTM D5185m	>5	---	---
Vanadium	ppm	ASTM D5185m		0	0
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	25	0	0
Barium	ppm	ASTM D5185m		0	0
Molybdenum	ppm	ASTM D5185m		<1	0
Manganese	ppm	ASTM D5185m		1	1
Magnesium	ppm	ASTM D5185m		<1	<1
Calcium	ppm	ASTM D5185m	17	16	20
Phosphorus	ppm	ASTM D5185m	200	208	225
Zinc	ppm	ASTM D5185m		87	87
Sulfur	ppm	ASTM D5185m	5000	5449	4596

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1
Sodium	ppm	ASTM D5185m		5	2
Potassium	ppm	ASTM D5185m	>20	1	0
Water	%	ASTM D6304	>0.03	0.012	0.007
ppm Water	ppm	ASTM D6304	>300	127.8	76.2

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		7951	---	1305
Particles >6µm	ASTM D7647	>5000	783	---	129
Particles >14µm	ASTM D7647	>640	8	---	11
Particles >21µm	ASTM D7647	>160	3	---	5
Particles >38µm	ASTM D7647	>40	1	---	0
Particles >71µm	ASTM D7647	>10	1	---	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	20/17/10	---	18/14/11



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.9	0.64	0.76	0.781





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	315	▲ 170	▲ 189.5	▲ 209

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0804477 **Received** : 26 May 2023
Lab Number : 05857924 **Diagnosed** : 30 May 2023
Unique Number : 10492389 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

ENERGIA EOLICA
 STA ANA KM25 CARRETERA AL SUR, A 1KM DEL CRUCE
 FRANCISCO MORAZAN, ZZ
 HN
 Contact: SANTOS DEL CID
 sdelcid@dennci.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: x:
 F: x: