




# PROBLEM SUMMARY

Sample Rating Trend



Area

9

Machine Id

**WINERGY GEARBOX WTG-903 (S/N 4836486-0020-4)**

Component


**Wind Turbine Gearbox**

Fluid

**FUCHS RENOLIN UNISYN CKC ISO 320 (340 LTR)**

## COMPONENT CONDITION SUMMARY

### ▲ Ferrous Alloys



## RECOMMENDATION

No corrective action is recommended at this time.  
Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL		
Iron	ppm	ASTM D5185m	>65	▲ 132	▲ 141	▲ 120

Customer Id: ENEFRA  
 Sample No.: WC0804482  
 Lab Number: 05857943  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 28 Mar 2022 Diag: Aaron Black

#### WEAR



We recommend an early resample to monitor this condition. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. Analytical ferrography: wear debris is normal with typical amounts of ferrous rubbing wear present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Analytical ferrography: contamination is normal with typical amounts of external debris present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 10 Mar 2021 Diag: Don Baldrige

#### WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. The iron level is abnormal. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 27 Jul 2020 Diag: Doug Bogart

#### WEAR



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All ferrographic tests and evaluation performed at WC Canada laboratory. An increase in the iron level is noted. All other component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





# OIL ANALYSIS REPORT

Sample Rating Trend

WEAR



Area

9

Machine Id


WINERGY GEARBOX WTG-903 (S/N 4836486-0020-4)

Component

Wind Turbine Gearbox

Fluid

FUCHS RENOLIN UNISYN CKC ISO 320 (340 LTR)



## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

The iron level is abnormal. All other component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0804482	WC05504530	WC0547231
Sample Date	Client Info		07 Mar 2023	28 Mar 2022	10 Mar 2021
Machine Age	mths	Client Info	83	67	120
Oil Age	mths	Client Info	83	0	65
Oil Changed	Client Info		Not Changed	N/A	Not Changed
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184	>50	12	22	23
Iron	ppm	ASTM D5185m	>65	▲ 132	▲ 141
Chromium	ppm	ASTM D5185m	>3	2	2
Nickel	ppm	ASTM D5185m	>3	0	<1
Titanium	ppm	ASTM D5185m	>10	0	0
Silver	ppm	ASTM D5185m		0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	0
Lead	ppm	ASTM D5185m	>5	0	<1
Copper	ppm	ASTM D5185m	>10	0	<1
Tin	ppm	ASTM D5185m	>10	<1	<1
Antimony	ppm	ASTM D5185m	>5	---	---
Vanadium	ppm	ASTM D5185m		0	0
Cadmium	ppm	ASTM D5185m		0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	25	0	1
Barium	ppm	ASTM D5185m		0	0
Molybdenum	ppm	ASTM D5185m		<1	0
Manganese	ppm	ASTM D5185m		1	1
Magnesium	ppm	ASTM D5185m		<1	0
Calcium	ppm	ASTM D5185m	17	1	8
Phosphorus	ppm	ASTM D5185m	200	182	208
Zinc	ppm	ASTM D5185m		<1	0
Sulfur	ppm	ASTM D5185m	5000	5934	4756

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	<1
Sodium	ppm	ASTM D5185m		5	4
Potassium	ppm	ASTM D5185m	>20	2	0
Water	%	ASTM D6304	>0.03	0.010	0.006
ppm Water	ppm	ASTM D6304	>300	103.8	65.2

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		1025	9431	457
Particles >6µm	ASTM D7647	>5000	165	511	95
Particles >14µm	ASTM D7647	>640	9	24	12
Particles >21µm	ASTM D7647	>160	1	4	4
Particles >38µm	ASTM D7647	>40	0	0	0
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	17/15/10	20/16/12	16/14/11



# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.9	<b>0.76</b>	0.83	0.823






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	315	<b>328</b>	323	329

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0804482 **Received** : 26 May 2023  
**Lab Number** : 05857943 **Diagnosed** : 30 May 2023  
**Unique Number** : 10492408 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

**ENERGIA EOLICA**  
 STA ANA KM25 CARRETERA AL SUR, A 1KM DEL CRUCE  
 FRANCISCO MORAZAN, ZZ  
 HN  
 Contact: SANTOS DEL CID  
 sdelcid@dennci.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: x:  
 F: x: