

PROBLEM SUMMARY


BATCH SYSTEM 3 Machine Id BS3 HOMO CRANKCASE

Component **Gearbox**

PETRO CANADA HYDREX AW 100 (--- LTR)

Sample Rating Trend ISO Dec2022 May/2023

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL	ABNORMAL				
Particles >4µm	ASTM D7647	>20000	<u> </u>	<u>^</u> 263612				
Particles >6µm	ASTM D7647	>5000	41394	1 47669				
Particles >14µm	ASTM D7647	>640	927	<u></u> 6010				
Oil Cleanliness	ISO 4406 (c)	>21/19/16	4 24/23/17	25/24/20				

Customer Id: KRAMASIOW Sample No.: USP248907 Lab Number: 05861893 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Change Filter	SKIPPED	Jun 05 2023	?	We recommend you service the filters on this component.
Other Action (see Note)	DONE	Jun 05 2023	?	No recommended actions

HISTORICAL DIAGNOSIS

12 Dec 2022 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. Appearance is milky. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.






OIL ANALYSIS REPORT

BATCH SYSTEM 3 **BS3 HOMO CRANKCASE**

Gearbox

PETRO CANADA HYDREX AW 100 (--- LTR)



ISO

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

)			Dec2022	May2023		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP248907	USP234445	
Sample Date		Client Info		26 May 2023	12 Dec 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>200	4	123	
Chromium	ppm	ASTM D5185m	>15	0	<1	
Nickel	ppm	ASTM D5185m	>15	0	0	
Titanium	ppm	ASTM D5185m		0	<1	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	6	
_ead	ppm	ASTM D5185m	>100	0	0	
Copper	ppm	ASTM D5185m	>200	3	<1	
Γin	ppm	ASTM D5185m	>25	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		<1	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	115	
Barium	ppm	ASTM D5185m	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	8	77	
Manganese	ppm	ASTM D5185m	0	0	2	
Magnesium	ppm	ASTM D5185m	0	<1	5	
Calcium	ppm	ASTM D5185m	50	49	14	
Phosphorus	ppm	ASTM D5185m	330	348	1072	
Zinc	ppm	ASTM D5185m	430	448	58	
Sulfur	ppm	ASTM D5185m	760	1188	21461	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	13	11	
Sodium	ppm	ASTM D5185m	>50	0	4	
Potassium	ppm	ASTM D5185m	>20	1	0	
Water Value	%	ASTM D6304		0.00	△ 0.234	
opm Water	ppm	ASTM D6304		0.00	△ 2340	
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	▲ 111693	263612	
Particles >6µm		ASTM D7647		▲ 41394	▲ 147669	
Particles >14µm		ASTM D7647	>640	▲ 927	▲ 6010	
Particles >21µm		ASTM D7647		83	▲ 1102	
Particles >38µm		ASTM D7647	>40	10	▲ 85	
•				9		
Particles >71µm Oil Cleanliness		ASTM D7647 ISO 4406 (c)	>10 >21/19/16	9 <u>4</u> 24/23/17	6 <u>25/24/20</u>	
FLUID DEGRADA	ΔΤΙΩΝ	method	limit/base	current	history1	history2
		ASTM D8045	0.60	0.45	3.04	HISTORYZ
Acid Number (AN)	mg KOH/g	MO 1 IVI D0045	0.00	0.45	5.04	



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: 05861893

Received : USP248907 : 10496358

: 01 Jun 2023 Diagnosed : 02 Jun 2023 Diagnostician : Doug Bogart

1022 12TH ST

MASON CITY, IA US 50401

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (641)421-2936

T: