

## **COOLANT REPORT**

Sam

Sample Rating Trend

NORMAL



# NX4099-C02

Component

Coolant

**HYBRID (HOAT) COOLANT (--- QTS)** 

#### Recommendation

The fluid is suitable for further service. Please note that this is a corrected copy for laboratory data updates.

#### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.


#### **Coolant Condition**

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.Boiling Point approximately 226F.

				May2023		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		WC0751365		
Sample Date		Client Info		17 May 2023		
Machine Age	kms	Client Info		0		
Oil Age	kms	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST F	RESULTS	method	limit/base	current	history 1	history 2
Specific Gravity		*ASTM D1298		1.070		
рН	Scale 0-14	ASTM D1287		9.72		
Nitrites	ppm	AP-053:2009		1276		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		52.6		
Freezing Point	°F	ASTM D3321		-40		
Total Dissolved Solids				222.0		
Carboxylate				fail		
CORROSION INH	IBITORS	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D6130		16		
Phosphorus	ppm	ASTM D6130		12		
Boron	ppm	ASTM D6130		377		
Molybdenum	ppm	ASTM D6130		19		
CORROSION		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D6130	>15	0		
Aluminum	ppm	ASTM D6130	>10	8		
Copper	ppm	ASTM D6130	>10	1		
Lead	ppm	ASTM D6130	>10	<1		
Tin	ppm	ASTM D6130	>10	<1		
Zinc	ppm	ASTM D6130		<1		
CONTAMINANTS	;	method	limit/base	current	history 1	history 2
Chlorine	ppm	ASTM D6130		32		
CARRIER SALTS		method	limit/base	current	history 1	history 2
Sodium	ppm	ASTM D6130		2416		
Potassium	ppm	ASTM D6130		1855		
SCALE POTENTI	AL	method	limit/base	current	history 1	history 2
Calcium	ppm	ASTM D6130	>100	<1		
Magnesium	ppm	ASTM D6130	>40	<1		
		*In-house				



## **COOLANT REPORT**





Iron/Tin/Silver	Reserve Alkalinity	
Abnormal .	14 <sub>T</sub> :	
iron	12 Abnormal	
nananananan Silver	10-	
	Reserve Alkalinity	
	o ve Alk	
	Ab	
	2 Abnormal	
23	04	
May17/23	May17/23 May17/23	
	≤ ≤ Freeze Point	
Copper/Aluminum/Lead	10 7	
copper aluminum	0	
annonnonna lead		
	§-10	
<u> </u>	20 Preeze Point (C)	
	-30	
1		
	-40	
C7	-50	
May17/23	May17/23 May17/23	
pH	Nitrites	
	Abnormal	
Abnormal	2500	
	2000	
Abnormal	第1500	
1		
	1000	
	500 - Abnormal	
May17/23	May17/23 +	



Laboratory

Sample No. Lab Number Unique Number : 10497184

: WC0751365 : 05862719

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

Diagnostician : Doug Bogart Test Package : COOL- (Additional Tests: COOL, Hardness, ICP)

: 14 Jun 2023

: 01 Jun 2023

**AVL POWERTRAIN ENGINEERING INC** 47519 HALYARD DRIVE PLYMOUTH, MI

US 48170-2438

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: