


# **OIL ANALYSIS REPORT**

#### Sample Rating Trend







# CRM54 CRM 54 MOTOR (S/N 16-2200-0700)

Bearing

AW HYDRAULIC OIL ISO 46 (--- QTS)

## Recommendation

### Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

The water content is negligible. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		12020 Jun20	020 Nov2020 Mar2021	Aug2021 Feb2022 Jun2022	Jan2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0034505	RP0030883	RP0031191
Sample Date		Client Info		31 May 2023	02 May 2023	07 Apr 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		17	13	8
Iron	ppm	ASTM D5185m	>20	0	2	2
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	0	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	2	2	2
Tin	ppm	ASTM D5185m	>20	12	13	12
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	5	0	0	1
Molybdenum	ppm	ASTM D5185m	5	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	25	0	1	0
Calcium	ppm	ASTM D5185m	200	52	53	51
Phosphorus	ppm	ASTM D5185m	300	341	328	342
Zinc	ppm	ASTM D5185m	370	390	431	426
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	1	2
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>2	0.003	0.006	0.005
ppm Water	ppm	ASTM D6304		35.8	63.8	56.1
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
A	1/011/	4 OTH 4 DOC 15	0.57	0.00	0.05	0.00

0.32

Acid Number (AN)

mg KOH/g ASTM D8045 0.57

0.35

0.23



# **OIL ANALYSIS REPORT**







Laboratory Sample No.

Lab Number **Unique Number** 

: 05863121 : 10497586 Test Package : IND 2 (Additional Tests: PQ)

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 02 Jun 2023 : RP0034505 Diagnosed : 05 Jun 2023

Diagnostician : Jonathan Hester

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**OUTOKUMPU STAINLESS USA** 

HWY 43 N CALVERT, AL US 36513

Contact: MARIO JOHNSON Mario.johnson@outokumpu.com

T: (251)321-4105 F: x: