




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**69-PC-23 (S/N 121)**

Component  
**Hydraulic System**

Fluid  
**MIL-PRF-83282 (--- LTR)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC05864813</b>	---	---
Sample Date	Client Info	<b>02 Jun 2023</b>	---	---
Machine Age	hrs Client Info	<b>0</b>	---	---
Oil Age	hrs Client Info	<b>0</b>	---	---
Oil Changed	Client Info	<b>N/A</b>	---	---
Sample Status		<b>NORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>20	<b>0</b>	---	---
Chromium ppm ASTM D5185m	>20	<b>0</b>	---	---
Nickel ppm ASTM D5185m	>20	<b>&lt;1</b>	---	---
Titanium ppm ASTM D5185m		<b>0</b>	---	---
Silver ppm ASTM D5185m		<b>0</b>	---	---
Aluminum ppm ASTM D5185m	>20	<b>0</b>	---	---
Lead ppm ASTM D5185m	>20	<b>0</b>	---	---
Copper ppm ASTM D5185m	>20	<b>0</b>	---	---
Tin ppm ASTM D5185m	>20	<b>0</b>	---	---
Vanadium ppm ASTM D5185m		<b>0</b>	---	---
Cadmium ppm ASTM D5185m		<b>8</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m		<b>0</b>	---	---
Barium ppm ASTM D5185m		<b>0</b>	---	---
Molybdenum ppm ASTM D5185m		<b>0</b>	---	---
Manganese ppm ASTM D5185m		<b>0</b>	---	---
Magnesium ppm ASTM D5185m		<b>0</b>	---	---
Calcium ppm ASTM D5185m		<b>0</b>	---	---
Phosphorus ppm ASTM D5185m		<b>818</b>	---	---
Zinc ppm ASTM D5185m		<b>1</b>	---	---
Sulfur ppm ASTM D5185m		<b>112</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>15	<b>&lt;1</b>	---	---
Sodium ppm ASTM D5185m		<b>0</b>	---	---
Potassium ppm ASTM D5185m	>20	<b>&lt;1</b>	---	---
Water % ASTM D6304	>0.05	<b>NEG</b>	---	---

## FLUID CLEANLINESS





method	limit/base	current	history1	history2
Particles >4µm ASTM D7647	>5000	<b>1325</b>	---	---
Particles >6µm ASTM D7647	>1300	<b>604</b>	---	---
Particles >14µm ASTM D7647	>160	<b>59</b>	---	---
Particles >21µm ASTM D7647	>40	<b>11</b>	---	---
Particles >38µm ASTM D7647	>10	<b>1</b>	---	---
Particles >71µm ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness ISO 4406 (c)	>19/17/14	<b>18/16/13</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D8045	0.1	<b>1.21</b>	---	---





# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	14.0	14.4	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC05864813     **Received** : 05 Jun 2023  
**Lab Number** : 05864813     **Diagnosed** : 07 Jun 2023  
**Unique Number** : 10499278     **Diagnostician** : Jonathan Hester  
**Test Package** : PLANT

**WOODWARD**  
 25200 W RYE CANYON RD  
 SANTA CLARITA, CA  
 US 91355  
 Contact: REYNARD GOLDMAN  
 reynard.goldman@woodward.com  
 T: (661)702-5991  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)