




# PROBLEM SUMMARY

Sample Rating Trend



INSOLUBLES



Machine Id

**ELION P3-OHIO (S/N 2017014501)**

Component


**Hydraulic System**

Fluid

**PETRO CANADA PURITY FG HYDRAULIC AW 68 (600 LTR)**

## COMPONENT CONDITION SUMMARY

### ▲ Varnish Potential



## RECOMMENDATION

No corrective action is recommended at this time.  
 The filtration at the time of sampling has been noted.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

| Sample Status         |       |            |     | <b>MARGINAL</b> | MARGINAL | MARGINAL |
|-----------------------|-------|------------|-----|-----------------|----------|----------|
| MPC Varnish Potential | Scale | ASTM D7843 | >15 | ▲ 22            | 6        | ▲ 21     |

**Customer Id:** IMLCAN  
**Sample No.:** WC0699214  
**Lab Number:** 05865111  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 30 Jan 2023 Diag: Doug Bogart

#### DEGRADATION



No corrective action is recommended at this time. The filter service at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. Linear Sweep Voltammetry (RULER– ASTM D6971) testing indicates a low amount of one of the anti-oxidants present in the oil, however, the other anti-oxidant(s) are still performing adequately. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Apr 2022 Diag: Doug Bogart

#### INSOLUBLES



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



### 23 Sep 2021 Diag: Doug Bogart

#### INSOLUBLES



The filter change at the time of sampling has been noted. We recommend that you use depth filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. We recommend an early resample to monitor this condition. Please note that this is a corrected copy for laboratory data updates. All component wear rates are normal. MPC (Membrane Patch Colorimetry) test indicates a high concentration of varnish present. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**INSOLUBLES**



Machine Id  
**ELION P3-OHIO (S/N 2017014501)**

Component  
**Hydraulic System**

Fluid  
**PETRO CANADA PURITY FG HYDRAULIC AW 68 (600 LTR)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filtration at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

MPC (Membrane Patch Colorimetry) test indicates a light concentration of varnish present. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

|               | method      | limit/base  | current            | history1    | history2    |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info |             | <b>WC0699214</b>   | WC0699213   | WC0503792   |
| Sample Date   | Client Info |             | <b>16 May 2023</b> | 30 Jan 2023 | 21 Apr 2022 |
| Machine Age   | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Age       | hrs         | Client Info | <b>12800</b>       | 11700       | 10000       |
| Oil Changed   | Client Info |             | <b>Filtered</b>    | Filtered    | Filtered    |
| Sample Status |             |             | <b>MARGINAL</b>    | MARGINAL    | MARGINAL    |

## WEAR METALS

|          | method | limit/base      | current    | history1 | history2 |
|----------|--------|-----------------|------------|----------|----------|
| Iron     | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Chromium | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Nickel   | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Titanium | ppm    | ASTM D5185m     | <b>0</b>   | 0        | 0        |
| Silver   | ppm    | ASTM D5185m     | <b>0</b>   | 0        | <1       |
| Aluminum | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Lead     | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Copper   | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Tin      | ppm    | ASTM D5185m >20 | <b>0</b>   | 0        | 0        |
| Antimony | ppm    | ASTM D5185m     | <b>---</b> | ---      | ---      |
| Vanadium | ppm    | ASTM D5185m     | <b>0</b>   | 0        | 0        |
| Cadmium  | ppm    | ASTM D5185m     | <b>0</b>   | 0        | 0        |

## ADDITIVES

|            | method | limit/base  | current      | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron      | ppm    | ASTM D5185m | <b>0</b>     | 0        | <1       |
| Barium     | ppm    | ASTM D5185m | <b>0</b>     | 0        | 0        |
| Molybdenum | ppm    | ASTM D5185m | <b>0</b>     | 0        | 0        |
| Manganese  | ppm    | ASTM D5185m | <b>0</b>     | 0        | 0        |
| Magnesium  | ppm    | ASTM D5185m | <b>&lt;1</b> | <1       | 0        |
| Calcium    | ppm    | ASTM D5185m | <b>&lt;1</b> | 2        | 2        |
| Phosphorus | ppm    | ASTM D5185m | <b>405</b>   | 400      | 414      |
| Zinc       | ppm    | ASTM D5185m | <b>0</b>     | 4        | 4        |
| Sulfur     | ppm    | ASTM D5185m | <b>1212</b>  | 1024     | 905      |

## CONTAMINANTS

|           | method | limit/base       | current      | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon   | ppm    | ASTM D5185m >15  | <b>1</b>     | 3        | 2        |
| Sodium    | ppm    | ASTM D5185m      | <b>&lt;1</b> | <1       | <1       |
| Potassium | ppm    | ASTM D5185m >20  | <b>&lt;1</b> | <1       | 0        |
| Water     | %      | ASTM D6304 >0.05 | <b>0.001</b> | ---      | ---      |
| ppm Water | ppm    | ASTM D6304 >500  | <b>1.3</b>   | ---      | ---      |


## FLUID CLEANLINESS

|                 | method       | limit/base | current        | history1 | history2 |
|-----------------|--------------|------------|----------------|----------|----------|
| Particles >4µm  | ASTM D7647   | >5000      | <b>49</b>      | 91       | 67       |
| Particles >6µm  | ASTM D7647   | >1300      | <b>19</b>      | 32       | 25       |
| Particles >14µm | ASTM D7647   | >160       | <b>2</b>       | 3        | 3        |
| Particles >21µm | ASTM D7647   | >40        | <b>1</b>       | 1        | 1        |
| Particles >38µm | ASTM D7647   | >10        | <b>0</b>       | 0        | 0        |
| Particles >71µm | ASTM D7647   | >3         | <b>0</b>       | 0        | 0        |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14  | <b>13/11/9</b> | 14/12/9  | 13/12/9  |




# OIL ANALYSIS REPORT


▲ Varnish Potential




Remaining Life (RULER)




Particle Count



Acid Number



Water (KF)




| FLUID DEGRADATION     | method   | limit/base | current | history1    | history2 |      |
|-----------------------|----------|------------|---------|-------------|----------|------|
| Acid Number (AN)      | mg KOH/g | ASTM D8045 | 0.26    | <b>0.21</b> | 0.20     | 0.24 |
| Anti-Oxidant 1        | %        | ASTM D6971 | <25     | <b>86</b>   | 86       | ---  |
| Anti-Oxidant 2        | %        | ASTM D6971 | <25     | <b>40</b>   | ▲ 22     | ---  |
| MPC Varnish Potential | Scale    | ASTM D7843 | >15     | ▲ <b>22</b> | 6        | ▲ 21 |

| VISUAL           | method | limit/base | current | history1     | history2 |       |
|------------------|--------|------------|---------|--------------|----------|-------|
| White Metal      | scalar | *Visual    | NONE    | <b>NONE</b>  | NONE     | NONE  |
| Yellow Metal     | scalar | *Visual    | NONE    | <b>NONE</b>  | NONE     | NONE  |
| Precipitate      | scalar | *Visual    | NONE    | <b>NONE</b>  | NONE     | NONE  |
| Silt             | scalar | *Visual    | NONE    | <b>NONE</b>  | NONE     | NONE  |
| Debris           | scalar | *Visual    | NONE    | <b>NONE</b>  | NONE     | NONE  |
| Sand/Dirt        | scalar | *Visual    | NONE    | <b>NONE</b>  | NONE     | NONE  |
| Appearance       | scalar | *Visual    | NORML   | <b>NORML</b> | NORML    | NORML |
| Odor             | scalar | *Visual    | NORML   | <b>NORML</b> | NORML    | NORML |
| Emulsified Water | scalar | *Visual    | >0.05   | <b>NEG</b>   | NEG      | NEG   |
| Free Water       | scalar | *Visual    |         | <b>NEG</b>   | NEG      | NEG   |

| FLUID PROPERTIES | method | limit/base | current | history1    | history2 |      |
|------------------|--------|------------|---------|-------------|----------|------|
| Visc @ 40°C      | cSt    | ASTM D445  | 63.34   | <b>71.3</b> | 66.0     | 65.7 |

SAMPLE IMAGES



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0699214 **Received** : 05 Jun 2023  
**Lab Number** : **05865111** **Diagnosed** : 12 Jun 2023  
**Unique Number** : 10499576 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, MPC, RULER )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**IML CONTAINERS OHIO**  
 5365 EAST CENTER DRIVE NORTHEAST, Suite D  
 CANTON, OH  
 US 44721

Contact: Juliana Nesello  
 sguiraldello@iml.com.br

T: (330)754-1066

F:

MPC (Varnish Test)



Sample Color & Clarity



*This page left intentionally blank*