


PROBLEM SUMMARY

Sample Rating Trend




WATER



Area
Boiler
Machine Id
Air compressor 3 (S/N 90808J)
Component
Air Compressor
Fluid
SUMMIT FG-200 ISO 46 (52 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. (Customer Sample Comment: Collected by cs)

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	---
Water	%	ASTM D6304	>0.6	🔴 95.3	0.007	---
ppm Water	ppm	ASTM D6304	>6000	🔴 953000	78.8	---
Silt	scalar	*Visual	NONE	🟡 HEAVY	NONE	---

Customer Id: DARDALTX
Sample No.: TO50001770
Lab Number: 05865623
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Change Filter	---	---	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

24 Apr 2023 Diag: Jonathan Hester

VISCOSITY




We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

view report





Area
Boiler
 Machine Id
Air compressor 3 (S/N 90808J)
 Component
Air Compressor
 Fluid
SUMMIT FG-200 ISO 46 (52 GAL)



DIAGNOSIS

Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. (Customer Sample Comment: Collected by cs)

Wear

All component wear rates are normal.

Contamination

There is a high concentration of water present in the oil. There is a high amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		TO50001770	TO50001579	---
Sample Date	Client Info		01 Jun 2023	24 Apr 2023	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			SEVERE	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	4	34	---
Chromium	ppm	ASTM D5185m >4	0	0	---
Nickel	ppm	ASTM D5185m >4	<1	0	---
Titanium	ppm	ASTM D5185m	0	0	---
Silver	ppm	ASTM D5185m	0	0	---
Aluminum	ppm	ASTM D5185m >10	<1	0	---
Lead	ppm	ASTM D5185m >20	0	12	---
Copper	ppm	ASTM D5185m >40	2	7	---
Tin	ppm	ASTM D5185m >5	<1	0	---
Vanadium	ppm	ASTM D5185m	0	0	---
Cadmium	ppm	ASTM D5185m	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	---
Barium	ppm	ASTM D5185m	2	0	---
Molybdenum	ppm	ASTM D5185m	0	3	---
Manganese	ppm	ASTM D5185m	<1	<1	---
Magnesium	ppm	ASTM D5185m	4	<1	---
Calcium	ppm	ASTM D5185m	5	36	---
Phosphorus	ppm	ASTM D5185m	13	269	---
Zinc	ppm	ASTM D5185m	22	66	---
Sulfur	ppm	ASTM D5185m	16	1081	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	19	---
Sodium	ppm	ASTM D5185m	0	0	---
Potassium	ppm	ASTM D5185m >20	1	<1	---
Water	%	ASTM D6304 >0.6	95.3	0.007	---
ppm Water	ppm	ASTM D6304 >6000	953000	78.8	---





FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	---	▲ 155185	---
Particles >6µm	ASTM D7647	>2500	---	▲ 12821	---
Particles >14µm	ASTM D7647	>320	---	292	---
Particles >21µm	ASTM D7647	>80	---	65	---
Particles >38µm	ASTM D7647	>20	---	6	---
Particles >71µm	ASTM D7647	>4	---	0	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	---	▲ 24/21/15	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.59	1.38	---

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	LIGHT	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	---
Free Water	scalar	*Visual		NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	46.7	---	▲ 144	---
Visc @ 100°C	cSt	ASTM D445	7.68	---	▲ 18.9	---
Viscosity Index (VI)	Scale	ASTM D2270	132	---	148	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					no image
Bottom					no image

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001770 **Received** : 06 Jun 2023
Lab Number : 05865623 **Diagnosed** : 08 Jun 2023
Unique Number : 10500088 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)